

Jawab : 8



Maharashtra State Electricity Distribution Co. Ltd.,
TESTING DIVISION SANGLI
PHONE : 2303280(P)
: 2301744(O)

No. EE/SGL/T/Lab/ 98

Date

14 FEB 2006

To,

M/S Suzlon Energy Ltd.,
9th Floor Godrej Milinium,
PUNE 1

Sub : Testing of HT TOD meters.

Ref : Your office Lr No. Nil dt. 30.1.05.

The HT TOD meters, BMP/Export type, having details as below have been tested at Testing Lab. Sangli.
Details of Meters.

1.	Make	M/s ELSTER Mumbai.
2.	Type	: ALPHA S+
3.	CT ratio	: -/1 Amp
4.	PT ratio	: 33 KV/110 V
5.	Imp./Unit	: 0.12
6.	SMP	: 100
7.	Class of accuracy	: 0.2
8.	Sr. Nos.	: 04738074, 04738075, 04738076, 04738077, 04738067, 04738073, 04738076, 04738079, 04738064, 04738058, 04738061, 04738039, 04738063, 04738060, 04738062.

The above meters are tested for calibration & dial test in BMP/Export mode & test results are observed be satisfactory.


Executive Engineer (T),
SANGLI

ARD 14/2*