


Request for 1st revision of monitoring plan (Validation Opinion)

Name of the entity (DOE)	JACO CDM, LTD
Title of the project activity	Gangwon Wind Park Project Reference No. 0222
Title/Subject (give a short title or specify the subject of your submission, maximum 200 characters):	Revision of monitoring plan to avoid the occurrence of non-conformity between the description of the initial monitoring plan and the actual situation
Date and signature for the DOE	Jan. 20, 2010 Tatsuo TANAKA 
Description of the request for Revision of the monitoring plan and relevant section of the PDD. <p>On 29 and 30 of January, 2009, the second verification (on-site assessment) was conducted for the Gangwon Wind Park Project activity in the monitoring period (01 Jan. 08 – 31. Dec. 08).</p> <p>In the Verification Report for issuance of above CERs, the DOE (JACO) stated that "It is stated in the PDD that the meters shall be calibrated when they are installed, and re-calibrated every two years after the installation". However, the Korea regulation (attachment 1) was amended in December 2007 and it has been recommended to revise the monitoring plan to meet the actual situation in Korea after the next calibration (August 2009)". In response to above DOE's comment, the Project Participants decided to modify the PDD and the Monitoring Manual after the following calibration was completed (August, 2009).</p> <p>To avoid above non-conformity, it is necessary to revise the initial monitoring plan. The latest version of KPX regulation was enacted on 30 of June, 2009.</p> <p>In the 1st revision, the operational and management structure is modified reflecting current situation.</p>	
Proposed revision of the monitoring plan <p>The 1st Revision of the Section D, Annex 4 and attachment 1 are attached.</p>	
Validation opinion <p>By the 1st revision, the non-conformity involved in the initial revision of the monitoring plan is avoided. In addition to that, the revision satisfies the conditions of the EB49 report Annex28 as follows.</p> <p>(a) The proposed revision is related to the frequency of meter calibration. In this project, the monitoring equipment of electricity was installed at the project site and the meter calibration will be conducted by KPX in accordance with KPX regulation. According to this situation, the revised monitoring plan is needed to avoid the non-conformity at the time of request for issuance of CERs (Appendix1 Background of 1st Revision)</p> <p>(b) The proposed revision is in the approved monitoring methodology ACM0002 / version 04. The proposed revised monitoring plan has modified the frequency of meter calibration in accordance with the approved monitoring methodology ACM0002 / version 04. The proposed revision will apply to verifications continuously.</p> <p>(c) JACO recommended the amendment of the initial monitoring plan at the second verification.</p>	

1st Revision of Monitoring Plan Gangwon Wind Park Project (Ref.No.0222)

Background of 1st Revision

From 29 to 30 January in 2009, the second verification (on-site assessment) was conducted by JACO CDM LTD. for the Gangwon Wind Park Project activity in the monitoring period (01 January, 2008 -31 December, 2008) and we were advised to revise the monitoring plan. We also added some modification to the organization chart.

1. The reason of change to the organization chart; until last year, Unison was majority shareholder of GaWiP and focal point of Gangwon CDM project. However Unison sold their GaWiP's shares to KEIF in last year and withdrawn project participant of Gangwon CDM project. Therefore Unison does not have any right for operating of GaWiP and Gangwon CDM project.

2. The reason of change to meter calibration: The Korean Government (Korea Power Exchange) recognized that 2 years term of meter calibration is too often. Therefore KPX changed "Regulation on Electric Operation" which stated that meter calibration shall be performed every 3.6 years for more than 1MW meter and in case of less than 1MW meter, it does not need calibration.