

 CDM: Response form for Request for revision of approved methodologies (version 01.1)	
<i>Date of Meth Panel meeting:</i>	9 – 13 August 2010
<i>Title and number of Request for revision</i>	Propose a new scenario (scenario 22) to include the situation in which biomass residues and fossil fuels are used in the baseline scenario AM_REV_0145
<u>Summary of the query:</u> Please use the space below to summarize the request for revision on the related approved methodologies.	
<p>ACM0006 “Consolidated methodology for electricity generation from biomass residues” is applicable to electricity generation project activities (cogeneration or not) using biomass residues, including greenfield power plants, power capacity expansion projects, energy efficiency improvement projects and fuel switch projects. The request for revision seeks to expand the applicability of ACM0006 by including a new scenario as follows:</p> <p>The project activity involves the installation of a new biomass residue fired cogeneration plant at a site where prior to the implementation of the project activity an existing biomass residue and fossil fuel fired cogeneration plant has also been operated.</p> <p>After the implementation of the project activity, the existing biomass residue and fossil fuel fired cogeneration plant either (a) continues to be operated next to the new biomass residue fired cogeneration plant (e.g. as back-up plant) or (b) could continue to be operated (i.e. it is fully operational and has a remaining technical lifetime) but is retired due to the installation of the new biomass residue fired cogeneration plant.</p> <p>The power generated by the project plant (a) would in the absence of the project activity be generated in the existing biomass residue and fossil fuel fired plant and may partly (b) be fed into the grid or be purchased from the grid in the absence of the project activity.</p> <p>The heat generated by the project plant would in the absence of the project activity be generated in the existing biomass residue and fossil fuel fired cogeneration plant.</p> <p>The biomass residues that would be used in the project plant would in the absence of the project activity used in the existing biomass residue and fossil fuel fired cogeneration plant at the project site.</p>	
<u>Recommendation by the Meth Panel:</u>	
(a) Please use the space below to provide amendments /changes (in your expert view, if necessary).	
Please, refer to the box below.	
(b) Please use the space below for providing guidance, as per Para 93 of EB25 Report, on what type of projects need to revise the PDD as a consequence of the suggested revision, if the recommendation is to revise the methodology.	
Please, refer to the box below.	

Answer to authors of the request for revision by the Meth Panel :

Please use the space below to provide an answer to the authors of the above query

The Meth Panel recommends [to approve](#) the request for revision. The proposed new scenario is covered by the revised version of ACM0006 "Consolidated methodology for electricity and heat generation from biomass residues" developed as part of the de-consolidation of the previous version of ACM0006.

Signed by the Chair, Mr. Lex de Jonge

Date: 13/08/2010

Signed by the Vice-Chair, Mr. Philip Gwage

Date: 13/08/2010

Information to be completed by the secretariat

F-CDM-AM	AM_REV_0145
Name of the authors of the query:	SGS
Date when the form was received at UNFCCC secretariat	13 August 2010
Date of transmission to the EB	13 August 2010
Date of posting in the UNFCCC CDM web site	13 August 2010