



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

**TYPE I - RENEWABLE ENERGY PROJECTS**

*Note: Categories I.A, I.B and I.C involve renewable energy technologies that supply electricity, mechanical and thermal energy, respectively, to the user directly. Renewable energy technologies that supply electricity to a grid fall into category I.D.*

All the approved small-scale methodologies, general guidance to the methodologies, information on additionality and abbreviations can be found at: <http://cdm.unfccc.int/methodologies/SSCmethodologies/approved.html>

**I.D. 'Grid connected renewable electricity generation'**

**Technology/measure**

1. This category comprises renewable energy generation units, such as photovoltaics, hydro, tidal/wave, wind, geothermal, and renewable biomass, that supply electricity to and/or displace electricity from an electricity distribution system that is or would have been supplied by at least one fossil fuel fired generating unit.
2. If the unit added has both renewable and non-renewable components (e.g. a wind/diesel unit), the eligibility limit of 15MW for a small-scale CDM project activity applies only to the renewable component. If the unit added co-fires fossil fuel, the capacity of the entire unit shall not exceed the limit of 15MW.
3. Biomass combined heat and power (co-generation) systems that supply electricity to and/or displace electricity from a grid are included in this category. To qualify under this category, the sum of all forms of energy output shall not exceed 45 MW<sub>thermal</sub>. E.g. for a biomass based co-generating system the rating for all the boilers combined shall not exceed 45 MW<sub>thermal</sub>.
4. Project activities adding renewable energy capacity should consider the following cases:
  - 1) Adding new units;
  - 2) Replacing old units for more efficient units.To qualify as a small scale CDM project activity, the aggregate installed capacity after adding the new units (case 1) or of the more efficient units (case 2) should be lower than 15 MW<sup>1</sup>.
5. Project activities that seek to retrofit or modify an existing facility for renewable energy generation are included in this category. To qualify as a small scale project, the total output of the modified or retrofitted unit shall not exceed the limit of 15 MW.

**Boundary**

6. The project boundary encompasses the physical, geographical site of the renewable generation source.

<sup>1</sup> Ex: 5 MW of new capacity is added to existing 9 MW to make the aggregate capacity of 14 MW which is within the allowed limits for capacity



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

**Baseline**

7. In the case of landfill gas, waste gas, wastewater treatment and agro-industries projects, recovered methane emissions are eligible under relevant type III categories (e.g. III.D, III.G, III.H, III.I). If the recovered methane is used for electricity generation the baseline shall be calculated in accordance with paragraphs below. If the recovered methane is used for heat generation it is eligible under category I.C.

8. For a system where all generators use exclusively fuel oil and/or diesel fuel, the baseline is the annual kWh generated by the renewable unit times an emission coefficient for a modern diesel generating unit of the relevant capacity operating at optimal load as given in Table I.D.1.

**Table I.D.1  
Emission factors for diesel generator systems (in kg CO<sub>2</sub>equ/kWh\*) for three different levels of load factor\*\***

Cases:	Mini-grid with 24 hour service	i) Mini-grid with temporary service (4-6 hr/day) ii) Productive applications iii) Water pumps	Mini-grid with storage
Load factors [%]	25%	50%	100%
<15 kW	2.4	1.4	1.2
>=15 <35 kW	1.9	1.3	1.1
>=35 <135 kW	1.3	1.0	1.0
>=135 <200 kW	0.9	0.8	0.8
> 200 kW***	0.8	0.8	0.8

\*) A conversion factor of 3.2 kg CO<sub>2</sub> per kg of diesel has been used (following revised 1996 IPCC Guidelines for National Greenhouse Gas Inventories)

\*\*) Figures are derived from fuel curves in the online manual of RETScreen International's PV 2000 model, downloadable from <http://retscreen.net/>

\*\*\*) default values

9. For all other systems, the baseline is the kWh produced by the renewable generating unit multiplied by an emission coefficient (measured in kg CO<sub>2</sub>equ/kWh) calculated in a transparent and conservative manner as:

(a) The average of the “approximate operating margin” and the “build margin”, where:



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

- (i) The “approximate operating margin” is the weighted average emissions (in kg CO<sub>2</sub>equ/kWh) of all generating sources<sup>2</sup> serving the system, excluding hydro, geothermal, wind, low-cost biomass, nuclear and solar generation;
- (ii) The “build margin” is the weighted average emissions (in kg CO<sub>2</sub>equ/kWh) of recent capacity additions to the system, based on the most recent information available on plants already built for sample group *m* at the time of PDD submission. The sample group *m* consists of either the five power plants that have been built most recently, or the power plant capacity additions in the electricity system that comprise 20% of the system generation (in MWh) and that have been built most recently. Project participants should use from these two options that sample group that comprises the larger annual generation. Power plant capacity additions registered as CDM project activities should be excluded from the sample group *m*. If 20% falls on part capacity of a plant, that plant is included in the calculation.

OR,

- (b) The weighted average emissions (in kg CO<sub>2</sub>equ/kWh) of the current generation mix.
- (c) Approximate Operating Margin emission factor and the weighted average emission factor can be calculated using either of the two following data vintages for years(s) *y*:
  - Option 1:  
A 3-year average, based on the most recent statistics available at the time of PDD submission.
  - Option 2:  
The year in which project generation occurs, if emission factor is updated based on ex post monitoring.
- (d) Build margin emission factor can be calculated using either of the following data vintages for years(s) *y*:
  - Option 1  
Most recent information available on plants already built at the time of PDD submission.
  - Option 2  
For the first crediting period, emission factor is updated based on ex-post monitoring. For subsequent crediting periods, emission factor should be calculated ex-ante, as described in option 1 above.

10. In the case of project activities adding renewable energy capacity, if the availability of renewable resources is limited, the impact of a decrease in electricity production from the units installed before the project implementation must be considered.

---

<sup>2</sup> Power plant capacity additions registered as CDM project activities should be excluded



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

For the specific case of hydropower plants, this effect could be considered calculating the production of electricity that must be used for emission reduction calculation with the following procedure:

- 1) To estimate every year during the crediting period, the energy that would have been produced in the same hydrological conditions by the units installed before the project;
- 2) The electricity production  $EG_y$  (MWh/ year) that must be considered to calculate emission reductions is calculated with the following formula:

$$EG_y = TE_y - WTE_y$$

where:

$TE_y$  the actual electricity produced in year  $y$  in the plant (all units)

$WTE_y$  the electricity that would have been produced by the units installed before the project under the hydrological conditions of year  $y$

11. For project activities that seek to retrofit or modify an existing facility for renewable energy generation the baseline scenario is the following:

In the absence of the CDM project activity, the existing facility would continue to provide electricity to the grid ( $EG_{baseline}$ , in MWh/year) at historical average levels ( $EG_{historical}$ , in MWh/year), until the time at which the generation facility would be likely to be replaced or retrofitted in the absence of the CDM project activity ( $DATE_{BaselineRetrofit}$ ). From that point of time onwards, the baseline scenario is assumed to correspond to the project activity, and baseline electricity production ( $EG_{baseline}$ ) is assumed to equal project electricity production ( $EG_y$ , in MWh/year), and no emission reductions are assumed to occur.

$EG_{baseline} = EG_{historical}$  until  $DATE_{BaselineRetrofit}$

$EG_{baseline} = EG_y$  on/after  $DATE_{BaselineRetrofit}$

Baseline emissions ( $BE_y$  in  $tCO_2$ ) are then, the product of the baseline emissions factor ( $EF_y$  in  $tCO_2/MWh$ ) calculated in paragraph 8 and 9, times the electricity supplied by the project activity to the grid ( $EG_y$  in MWh) minus the baseline electricity supplied to the grid in the case of modified or retrofit facilities ( $EG_{baseline}$  in MWh), as follows:

$$BE_y = (EG_y - EG_{baseline}) \cdot EF_y$$

$EG_{historical}$  is the average of historical electricity delivered by the existing facility to the grid, spanning all data from the most recent available year (or month, week or other time period) to the time at which the facility was constructed, retrofit, or modified in a manner that significantly affected output (i.e., by 5% or more), expressed in MWh per year. A minimum of 5 years (120 months) (excluding abnormal years) of historical generation data is required in the case of hydro facilities. For other facilities, a minimum of 3 years data is required. In the case that 5 years of historical data (or three years in the case of non hydro project activities) are not available - e.g., due to recent retrofits or exceptional circumstances as described in



**Indicative simplified baseline and monitoring methodologies  
for selected small-scale CDM project activity categories**

*I.D. Grid connected renewable electricity generation (cont)*

---

footnote<sup>3</sup> 1 - a new methodology or methodology revision must be proposed.

All project electricity generation above baseline levels (EG<sub>baseline</sub>) would have otherwise been generated by the operation of grid-connected power plants and by the addition of new generation sources, as reflected in the combined margin (CM) calculations described.

In order to estimate the point in time when the existing equipment would need to be replaced in the absence of the project activity (DATE<sub>BaselineRetrofit</sub>), project participants may take the following approaches into account:

- (a) The typical average technical lifetime of the type equipment may be determined and documented, taking into account common practices in the sector and country, e.g. based on industry surveys, statistics, technical literature, etc.
- (b) The common practices of the responsible company regarding replacement schedules may be evaluated and documented, e.g. based on historical replacement records for similar equipment. The point in time when the existing equipment would need to be replaced in the absence of the project activity should be chosen in a conservative manner, i.e. if a range is identified, the earliest date should be chosen.

### **Leakage**

12. If the energy generating equipment is transferred from another activity or if the existing equipment is transferred to another activity, leakage is to be considered.

### **Monitoring**

13. Monitoring shall consist of metering the electricity generated by the renewable technology. In the case of co-fired plants, the amount of biomass and fossil fuel input shall be monitored.

---

<sup>3</sup> Data for periods affected by unusual circumstances such as natural disasters, conflicts, and transmission constraints shall be excluded