

Reply to SSC_021
06 June 2005

Subject: RE: Interpretation of AMS I.D.

The SGS view is correct, but needs to be clarified. It's 20% of the total EXISTING capacity. So if there's 10,000 GWh of generation in the system (during the most recent historical year), you look for the most recent plants until their total generation equals or exceeds 2000 GWh. Make sense?