

 <p style="text-align: center;">CDM: Revision Form for Approved Methodologies (version 01) <i>(To be used for responding to requests for clarifications on approved methodologies)</i></p>	
<i>Date of Meth Panel meeting:</i>	31 January - 03 February 2006
<i>Title/Subject (give a small title or specify the subject of your submission, maximum 200 characters):</i>	“Applicability of AM0014 to projects that supply small amounts of excess electricity to the grid”
<i>Indicative methodology to which your submission relates</i>	AM0014 - Natural gas-based package cogeneration
<i>Name of the authors of the query:</i>	Det Norske Veritas Certification Ltd
Summary of the query: Please use the space below to summarize the request for clarification on the related approved methodologies.	
>> One of the applicability conditions of AM0014 in its current form is that “no excess electricity is supplied to the power grid and no excess heat from the cogeneration system is provided to another user”. The Meth Panel is requested to consider whether AM0014 can also be applied by projects whose main objective is to supply electricity and heat to designated consuming facilities, but which may supply small amounts of electricity to the grid.	
Recommendation by the Meth Panel: Please use the space below to provide amendments /changes (in your expert view, if necessary).	
>> The Meth Panel agreed that, based on the documentation provided with the request for clarification by the DOE, that the applicability conditions of AM0014 should not be expanded to also apply to projects that may also supply small amounts of electricity to the grid, as this would imply significant modifications in the methodology, for which the methodology was not originally developed.	
Answer to authors of the request for clarification by the Meth Panel : Please use the space below to provide an answer to the authors of the above query	
>> The Meth Panel agreed that the documentation provided with the request for clarification was not complete as no amendments to the approved methodology was provided by the DOE, and that the applicability conditions of AM0014 should not be expanded to also apply to projects that may also supply small amounts of electricity to the grid, as this would imply significant modifications in the methodology, for which the methodology was not originally developed.	



Signature of the Meth Panel Chair

Date: 13 / 02/06

(Jean-Jacques Becker)



Signature of the Meth Panel Vice-Chair

Date: 13 / 02/06

(José Miguez)

Information to be completed by the secretariat

F-CDM-AM	F-CDM-AM0014
Date when the form was received at UNFCCC secretariat	13 February 2006
Date of transmission to the EB	13 February 2006
Date of posting in the UNFCCC CDM web site	13 February 2006