

reference 1: the explanation on the electricity generated and supplied to the grid by the Nanlinghe 1st Level Hydropower station

关于南令河一级电站发电

南令河一级电站装机 8MW, 于 2009 年 1 月份投产试运行, 至今已发电 10 个月, 各月份的发电量和上网电量如下:

日 期	发电量 (度)	上网电量(度)	线损及自用电率
2009.1.9-2009.1.20	533680	492820	7.66%
2009.1.21-2009.2.20	1491060	1380700	7.40%
2009.2.21-2009.3.20	1364580	1258640	7.76%
2009.3.21-2009.4.20	1474000	1361690	7.62%
2009.4.21-2009.5.20	1440460	1325980	7.95%
2009.5.21-2009.6.20	1805870	1670830	7.48%
2009.6.21-2009.7.20	2404140	2228381	7.31%
2009.7.21-2009.8.20	2928360	2704320	7.65%
2009.8.21-2009.9.20	2979020	2760150	7.35%
2009.9.21-2009.10.20	3074520	2840330	7.62%
总计	19495690	18023841	7.55%

临沧市新永电开发有限公司



the explanation on the electricity generated and supplied to the grid

by the Nanlinghe 1st level hydropower station

the installed capacity of Nanlinghe 1st level hydropower station is 8MW, and has been put into operation in Jan.2009. the detailed electricity generated and supplied to the grid by the Project showed as follow:

date	Electricity generated (kw.h)	Electricity supplied to the grid (kw.h)	Transmission rate and self-used rate
2009.1.9-2009.1.20	533680	492820	7.66%
2009.1.21-2009.2.20	1491060	1380700	7.40%
2009.2.21-2009.3.20	1364580	1258640	7.76%
2009.3.21-2009.4.20	1474000	1361690	7.62%
2009.4.21-2009.5.20	1440460	1325980	7.95%
2009.5.21-2009.6.20	1805870	1670830	7.48%
2009.6.21-2009.7.20	2404140	2228381	7.31%
2009.7.21-2009.8.20	2928360	2704320	7.65%
2009.8.21-2009.9.20	2979020	2760150	7.35%
2009.9.21-2009.10.20	3074520	2840330	7.62%
Total	19495690	18023841	7.55%