



AVANT-GARDE ENGINEERS AND CONSULTANTS (P) LTD.
REGD. OFFICE : 68A, PORUR KUNDRATHUR HIGH ROAD, PORUR, CHENNAI - 600 116
TEL. : 91-44-4827843, 4828532, 4828717, 18, 19, 20 FAX : 91-44-4828531
Email : avantgarde@vsnl.com
Web Site : <http://www.avantgarde-india.com>

18.10.2002

To
M/s. Bhushan Limited
6th Floor, J.K. Millennium Centre
46D, J.L. Nehru Road
Kolkata - 700 071

Kind Attn: Mr. R.N. Yadav - Vice President


Dear Sir,

Based on the detailed discussion had with you and your technical team with our design Engineers on 16.10.2002, our comments are as follows:-

"The AFBC Boilers can be operated with operating capacity of 90% and above. Whereas, you will be able to operate WHRB with an overall capacity of about 60%, due to the nature of operation of DR Kilns".

Thanking You,

For Avant-Garde Engineers & Consultants Ltd.,


S. Soundararajan
Chief-Engineering (Mechanical)



मेकॉन लिमिटेड
भारत सरकार का संस्थान

MECON LIMITED
A Government of India Enterprise

राँची/Ranchi-834002, झारखण्ड/Jharkhand, भारत/India
फोन/Phone : 0651-480002 / 480216
फैक्स/Fax : 0651-482189/482214
ई-मेल/E-mail : mecon-rnch@mecon.co.in
वेबसाइट/website : <http://www.meconlimited.com>

16.12.2002

To,
M/s.Bhushan Limited
6th Floor, J.K.Millennium Centre
46D, J.L.Nehru Road
Kolkata – 700 071


Kind Attn: Mr. R.N. Pattajoshi

Dear Sir,

This has reference to the discussions we had with you with regard to availability of production from the DRI Kiln of 500 TPD. This is possible only when quality of coal/iron ore is maintained as specified. In case you depend on the quality as available in the region, the production may come down to about 60/70% with corresponding reduction of steam generation. The AFBC boiler operating capacity can be 90%.

Thanking you,

Yours faithfully,
For MECON LIMITED


(J.S. Sahay)
Dy.GM (SMS) & PC