

## Er. Abhay K. Rastogi

B.Sc., B.E. (MECH) ROORKEE, F.I.E.  
CHARTERED ENGINEER (F/101830/9)  
SURVEYOR & LOSS ASSESSOR (SLA 10722)  
Ex. DIRECTOR, BAREILLY CORPN. BANK LTD.  
PAN No. AAOPR8786J  
S.T.C. No. AAOPR-8786-J-ST

Phone: Resi (0591) 2493449  
Off (0591) 6535670  
Rim (0591) 3291739  
Mobile: 98370-33513  
Email: cool100\_202@hotmail.com  
A-53, LAJPAT NAGAR,  
MORADABAD - 244 001.

Ref. no. 067/CE/1310

Dated 06.10.2006

### INSPECTION CERTIFICATE

#### (TURBINE)

Upon the request of Shri Neeraj Agarwal, Chief Engineer of M/s DSM Sugar Asmoli, Distt. Moradabad, the undersigned visited the plant on 05.10.06 to inspect the turbines installed in the unit. The turbine were physically examined and necessary records checked for the above said purpose. After completion of the assignment, I have to report as here under:-

1. Date of inspection : Conducted on 05.10.06 at Asmoli.
2. Name of owner : DSM Sugar, Asmoli, Distt. Moradabad.

#### Details of Turbine

<u>S.No.</u>	<u>Description &amp; Specification</u>	<u>Yr. of installation</u>
01.	Turbine, 5 MW, working Pressure 60 Kg./cm sq. Make Kessel	1994-95
02.	Turbine, 5 MW, working Pressure 64 Kg./cm sq. Make Kessel	1994-95
03.	Turbine, 5 MW, working Pressure 64 Kg./cm sq. Make Kessel	1995-96
04.	Turbine, 5 MW, working Pressure 64 Kg./cm sq. Make Kessel	1996-97
05.	Turbine, 11MW, working Pressure 64 Kg./cm sq. Make Seimens	2006-07

Er. ABHAY K. RASTOGI  
CHARTERED ENGINEER  
F-101830/9 Dt. 24.10.93  
A-53, LAJPAT NAGAR,  
MORADABAD-244 001




Remarks & Observations:-

01. All parts of the above noted turbines have been visually checked and found to be in satisfactory working condition.
02. The present external condition of the turbines listed above has been found to be good to the extent that expected residual life of the same is approximately 15 years at 8000 operation hour per year.
03. I have no direct or indirect interest in any of the machines listed above.
04. This inspection report / certificate is being issued without any prejudice.

Date : 06.10.2006

Place : Moradabad

Signature of Chartered Engineer



Name in Block Letters

ER. ABHAY K. RASTOGI

Designation

Chartered Engineer

Address

A-53, Lajpat Nagar, Moradabad.

Telephone No.

0591-2493449

Name & Address of the

Institution

The Institution of Engineers (India)

8, Gokhale Road, Calcutta.

Ref. No. & Date of Corporate

Membership

F-101830/9 dt. 26.02. 1993

**Er. ABHAY K. RASTOGI**

**CHARTERED ENGINEER**

**F-101830/9 Dt. 26-02-93**

**A-53, LAJPAT NAGAR,**

**MORADABAD-241 001**