

Er. Abhay K. Rastogi

B.Sc., B.E. (MECH) ROORKEE, F.I.E.
CHARTERED ENGINEER (F/101830/9)
SURVEYOR & LOSS ASSESSOR (SLA 10722)
Ex. DIRECTOR, BAREILLY CORPN. BANK LTD.
PAN No. AAOPR8786J
S.T.C. No. AAOPR-8786-J-ST

Phone: Resi (0591) 2493449
Off (0591) 6535670
Rim (0591) 3291739
Mobile: 98370-33513
Email: cool100_202@hotmail.com
A-53, LAJPAT NAGAR,
MORADABAD - 244 001.

Ref. no. 067/CE/1309

Dated 06.10.2006

INSPECTION CERTIFICATE

(BOILERS)

Upon the request of Shri Neeraj Agarwal, Chief Engineer of M/s DSM Sugar Asmoli, Distt. Moradabad, the undersigned visited the plant on 05.10.06 to inspect the boilers installed in the unit. The boilers were physically examined and necessary records checked for the above said purpose. After completion of the assignment, I have to report as here under:-


1. Date of inspection : Conducted on 05.10.06 at Asmoli.
2. Name of owner : DSM Sugar, Asmoli, Distt. Moradabad.

Details of Boilers

<u>S.No.</u>	<u>Description & Specification</u>	<u>Identification no.</u>	<u>Yr. of installation</u>
01.	80 TPH, 64 Kg/cm sq., Temp, 480 D.C., BW Boiler, H.S.2815 mtr.Sq.	MP 3009	1994-95
02.	80 TPH, 64 Kg/cm sq., Temp, 480 D.C., BW Boiler, H.S.2428 mtr.Sq.	GT 759	1995-96

Remarks & Observations:-

01. All parts of the above noted boilers have been visually checked and found to be in satisfactory working condition.
02. The present external condition of the boilers listed above has been found to be good to the extent that expected residual life of the same is approximately 15 years at 8000 operation hour per year.



Er. ABHAY K. RASTOGI
CHARTERED ENGINEER
F-101830/9 Dt. 26-02-93
A-53, LAJPAT NAGAR,
MORADABAD-244 001


03. I have no direct or indirect interest in any of the machines listed above.

04. This inspection report / certificate is being issued without any prejudice.

Date : 06.10.2006

Place : Moradabad

Signature of Chartered Engineer



Name in Block Letters

ER. ABHAY K. RASTOGI

Designation

Chartered Engineer

Address

A-53, Lajpat Nagar, Moradabad.

Telephone No.

0591-2493448

Name & Address of the Institution The Institution of Engineers (India)

8, Gokhle Road, Calcutta.

Ref. No. & Date of Corporate

Membership

F-101830/9 dt. 26.02.1993

Er. ABHAY K. RASTOGI

CHARTERED ENGINEER

F-101830/9 Dt. 26-02-93

A-53, LAJPAT NAGAR,

MORADABAD-241 001

S.No. Description & Specification

01. 20 T.P.H. 64 Kg. Com. Pump

1800 C.C. 30W. Motor H.S.2425

02. 80 T.P.H. 64 Kg. Com. Pump

4800 C.C. 30W. Motor H.S.2425

Remarks & Observances

01. All parts of the above noted pump & motor are in good working condition.

satisfactory working condition.

02. The present estimated condition of the pump & motor has been found to be good.

It is noted that the pump & motor are approximately 15 years old.

Signature of Inspecter