



Monitoring report form for CDM programme of activities
(Version 02.0)

Complete this form in accordance with the instructions attached at the end of this form.

MONITORING REPORT

Title of the PoA	Accelerating Electrification through Grid Extension and Off-Grid Electrification in Rural Areas of Uganda	
UNFCCC reference number of the PoA	10186	
Version numbers of the PoA-DD applicable to this monitoring report	6.0	
Version number of this monitoring report	1.0	
Completion date of this monitoring report	12/04/2018	
Monitoring period number	First Monitoring Period	
Duration of this monitoring period	28/08/2015 – 03/05/2017	
Monitoring report number for this monitoring period	1	
Coordinating/managing entity	Rural Electrification Agency Uganda	
Host Parties	Host Party of the PoA	Is this the host Party of a CPA covered in this monitoring report? (yes/no)
	The Republic of Uganda	Yes
Sectoral scopes	Sectoral Scope 1 – Energy Industries (renewable- / non-renewable sources) Sectoral Scope 2 – Energy Distribution	
Applied methodologies and standardized baselines	AMS-I.L Version 3 Electrification of Rural Communities Using Renewable Energy AMS-III.AR Version 5 Substituting Fossil Fuel Based Lighting with LED/CFL Lighting Systems AMS-III.BB Version 2 Electrification of Communities Through Grid Extension or Construction of New Mini-Grids	
Amount of GHG emission reductions or net anthropogenic GHG removals achieved by all CPAs covered in this monitoring report in this monitoring period	Amount achieved before 1 January 2013	Amount achieved from 1 January 2013
	0 tCO ₂ e	1,518 tCO ₂ e

Amount of GHG emission reductions or net anthropogenic GHG removals estimated ex ante for this monitoring period in the CPA-DDs for the CPAs covered in this monitoring report	12,833 tCO ₂ e
--	---------------------------

PART I Monitoring of programme of activities (PoA)

SECTION A. Description of PoA

A.1. General description of PoA

Policy Measure/Stated Goal:

The micro-scale PoA will expanded access to electricity in Uganda through extensions of existing grids (AMS-III.BB Version 2), off-grid electrification (AMS-I.L Version 3), and solar powered lighting systems (AMS-III.AR Version 5). The proposed PoA combined these three methodologies to increase access to electricity within the PoA boundary. CPAs under the PoA implements AMS-I.L, AMS-III.AR, or AMS-III.BB methodologies. The proposed PoA covers sectoral scopes 1 and 2.

The Government has articulated the “Uganda Vision 2040” that lays out broad policy directives and sets out a target of increasing access to electricity to 80 per cent by 2040. The First Rural Electrification Strategy and Plan (RESP-1) set the target of electrification rate in rural area from 1% in 2001 to 10% in 2010. However, the implementation of RESP-1 has been slow-paced. The rural access to electricity as of mid 2013 is reported to be around 7%¹.

To address the challenges of low electricity access rates, a new Rural Electrification Strategy and Plan (2013-2022) (RESP II) was formulated by the Ministry of Energy and Mineral Development (MEMD) and approved by the Cabinet in July 2013 that aims to increase access to electricity in the rural areas to 26% by the year 2022. This would require 140,000 connections from solar home systems (SHS) and mini-grids and 1.3 million new grid connections.

The proposed PoA reduces greenhouse gas emissions by electrifying households and institutions in Uganda through installation of renewable energy systems, distribution of LED/CFL lighting systems, or connection to the national grid, thereby reducing the consumption of fossil fuels used in the current scenario and preventing emissions of greenhouse gases.

Framework for the Implementation of the PoA:

The PoA increases access to electricity within the PoA boundary through three types of technologies. The PoA covers grid extension, off-grid electrification, and solar powered LED lighting systems. The PoA implements these three technology types through the following methodologies:

- AMS-I.L Version 3 Electrification of Rural Communities Using Renewable Energy
- AMS-III.AR Version 5 Substituting Fossil Fuel Based Lighting with LED/CFL Lighting Systems
- AMS-III.BB Version 2 Electrification of Communities Through Grid Extension or Construction of New Mini-Grids

CPAs under the PoA implement AMS-III.BB Version 2 (Type A), AMS-III.AR Version 5 (Type B), or AMS-I.L Version 3 (Type C).

¹ Uganda Bureau of Statistics. Uganda Rural Electrification Survey 2012. December 2013. Page 20.

The implementation of the PoA is managed by the CME. The CME works with the service and technology providers to facilitate connections to the national grid (CPA Type A), distribution of LED/CFL lighting systems (CPA Type B), or electrify rural communities using renewable energy (CPA Type C). For all CPA types, the CME acts as a coordinator and operate the electronic data management system that stores information on and track all technologies under the PoA.

Under Type A CPAs, the CME acts as the CPA Implementer. Service Providers (SPs) govern grid-connections in the 13 different service territories in Uganda. Under the proposed PoA the SPs work to facilitate the connection of households and institutions/SMEs to the national grid by reducing the connection fee, providing connection materials, or supporting the connection in other ways using the revenue from CER sales. The CME/CPA Implementer coordinates the extension of the national grid in the CPA boundary and disburse the financing and materials for the grid connections. The different Type A CPAs are distinguished from one another by the region they cover. Each Type A CPA covers one or more service territories within the PoA boundary

Under Type B CPAs, the CME works with manufacturers and distributors of solar powered lighting systems to distribute solar powered efficient lights to end-users within the PoA boundary. The CME acts as the CPA Implementer. The CME/CPA Implementer will select and manage the distribution of technologies under Type B CPAs as well as oversee the data collection process for monitoring and verification. Manufacturers will produce the technologies distributed under the CPA and distributors will import and perform last mile distribution of technologies. Revenues from the sale of CERs will go to subsidize the cost of the lighting system, support the distribution of the technology, or educate end-users on the benefits of solar powered lighting systems.

Under Type C CPAs, the CME will act as the CPA Implementer, to provide electricity to off-grid rural communities. The CME/CPA Implementer will select and manage the distribution of technologies under Type C CPAs as well as oversee the data collection process for monitoring and verification. Solar vendors will import and distribute the technologies under the CPA and work with the CME/CPA Implementer to collect the required end-user information. The solar vendors will provide solar power systems under the PoA to the end-user at a lower up front or financing cost depending on the business model of the solar vendor.

A.1.1. Corresponding generic component project activities (CPAs)

Title and reference number of the corresponding generic CPA	Version of the PoA-DD	Sectoral scopes	Applied methodologies and standardized baselines
<p>Title: Accelerating Electrification through Grid Extension and off-grid electrification in Rural Areas of Uganda CPA</p> <p>CPA Type: Generic CPA Type A</p>	6.0	2	<p>AMS-III.BB Electrification of communities through grid extension or construction of new mini-grids Version 2.0²</p> <p>AMS-I.D Grid connected renewable electricity generation Version 18.0³</p> <p>AMS-I.F Renewable electricity generation for captive use and min-grid Version 3.0⁴</p> <p>AMS-I.L Electrification of rural communities using renewable energy Version 3.0⁵</p> <p>AM0045 Grid connection of isolated electricity systems Version 2.0⁶</p> <p>AM0104 Interconnection of electricity grids in countries with economic merit order dispatch Version 2.0⁷</p> <p>Tool to calculate the emission factor for an electricity system Version 4.0⁸</p> <p>General Guidelines for SSC CDM methodologies Version 20.0⁹</p> <p>Standard on sampling and surveys for CDM project activities and PoAs Version 2.0¹⁰</p>

² <https://cdm.unfccc.int/methodologies/DB/TI8KFU0GX1JBYZLOIJ6OMCSVYXCZUJ>

³ <https://cdm.unfccc.int/methodologies/DB/W3TINZ7KKWCK7L8WTFQQOFQQH4SBK>

⁴ <https://cdm.unfccc.int/methodologies/DB/9KJWQ1G0WEG6LKHX21MLPS8BQR7242>

⁵ <https://cdm.unfccc.int/methodologies/DB/CCZKY3FSL1T28BNEGDRSCKS0CY0WVA>

⁶ <https://cdm.unfccc.int/methodologies/DB/0XHXSW8OSSITEWX2YMKTBIL4R05OX5>

⁷ <https://cdm.unfccc.int/methodologies/DB/OEZDV2912B4QUOOC5W7RC2JDP9BQTD>

⁸ <https://cdm.unfccc.int/methodologies/PAmethodologies/tools/am-tool-07-v4.0.pdf>

⁹ http://cdm.unfccc.int/Reference/catalogue/document?doc_id=000003495

¹⁰ https://cdm.unfccc.int/public_inputs/2011/eb63_05/draft_standard_sampling.pdf

CDM-PoA-MR-FORM

Title and reference number of the corresponding generic CPA	Version of the PoA-DD	Sectoral scopes	Applied methodologies and standardized baselines
<p>Title: Accelerating Electrification through Solar Lamps in Rural Areas of Uganda CPA</p> <p>CPA Type: Generic CPA Type B</p>	6.0	1	<p>AMS-III.AR Substituting fossil fuel based lighting with LED/CFL lighting systems Version 5.0¹¹</p> <p>AMS-I.D Grid connected renewable electricity generation Version 18.0¹²</p> <p>AMS-I.F Renewable electricity generation for captive use and min-gird Version 3.0¹³</p> <p>General guidelines for SSC CDM methodologies Version 20.0¹⁴</p>
<p>Title: Accelerating Electrification through SHS in Rural Areas of Uganda CPA</p> <p>CPA Type: Generic CPA Type C</p>	6.0	1	<p>AMS-I.L Electrification of Rural Communities Using Renewable Energy Version 3.0¹⁵</p> <p>AMS-I.D Grid connected renewable electricity generation Version 18.0¹⁶</p> <p>AMS-I.F Renewable electricity generation for captive use and min-gird Version 3.0¹⁷</p> <p>General guidelines for SSC CDM methodologies Version 20.0¹⁸</p> <p>General guidance on leakage in biomass project activities Version 3.0 (attachment C to Appendix B)¹⁹</p>

A.1.2. CPAs included in the PoA

Title and UNFCCC reference number of the CPA	Title and reference number of the corresponding generic CPA	Version of the PoA-DD	Crediting period type and duration	Covered in this monitoring report? (yes/no)
<p>Accelerating Electrification through Grid Extension and off-grid electrification in Rural Areas of Uganda CPA 1</p>	<p>Title: Accelerating Electrification through Grid Extension and off-grid electrification in Rural Areas of Uganda CPA</p> <p>CPA Type: CPA Type A</p>	6.0	<p>Type: Fixed</p> <p>Duration: 28/08/2015 to 27/08/2025</p>	Yes

¹¹ <http://cdm.unfccc.int/methodologies/DB/4K7KI9GY79UEHUKF3140PCID64IXCV>

¹² <https://cdm.unfccc.int/methodologies/DB/W3TINZ7KKWCK7L8WTXFQQOFQQH4SBK>

¹³ <https://cdm.unfccc.int/methodologies/DB/9KJWQ1G0WEG6LKHX21MLPS8BQR7242>

¹⁴ http://cdm.unfccc.int/Reference/catalogue/document?doc_id=000003495

¹⁵ <https://cdm.unfccc.int/methodologies/DB/CCZKY3FSL1T28BNEGDRSCKS0CY0WVA>

¹⁶ <https://cdm.unfccc.int/methodologies/DB/W3TINZ7KKWCK7L8WTXFQQOFQQH4SBK>

¹⁷ <https://cdm.unfccc.int/methodologies/DB/9KJWQ1G0WEG6LKHX21MLPS8BQR7242>

¹⁸ http://cdm.unfccc.int/Reference/catalogue/document?doc_id=000003495

¹⁹ https://cdm.unfccc.int/Reference/Guidclarif/ssc/methSSC_guid04.pdf

Reference Number: 10186-0001				
Accelerating Electrification through Grid Extension and off-grid electrification in Rural Areas of Uganda CPA 2	Title: Accelerating Electrification through Grid Extension and off-grid electrification in Rural Areas of Uganda CPA	6.0	Type: Fixed Duration: 04/05/2017 to 03/05/2027	No
Reference Number: 10186-0002	CPA Type: CPA Type A			

A.2. Coordinating/managing entity

The Rural Electrification Agency Uganda (REA) is the CME of the PoA.

REA is a semi- autonomous agency under the Minister of Energy and Mineral Development through Uganda's Statutory Instrument 2001 no. 75, to operationalize the government's rural electrification function under a public-private partnership. It functions as the secretariat of the Rural Electrification Board which carries out the Minister's rural electrification responsibilities, as defined in the Electricity Act of 1999.

SECTION B. Implementation of PoA

B.1. Description of implemented PoA

To date, REA has worked with the Service Providers (SPs) to implement Type A CPAs, e.g. facilitating the extension of the national grid to connect end-users to the grid. The various measures used to facilitate the connection of households and institutions/SMEs to the national grid included reducing the connection fee, providing connection materials, or wholesale purchase of connection materials.

The two included CPAs included under the PoA to date cover all 13 service territories in Uganda. With CPA 1 covering 1 and CPA 2 covering the remaining 12. For this monitoring report, 5 Service Providers have provided monitoring data to determine the resulting emission reductions. The table below summarizes the respective service providers, number of connections, electricity consumed, and estimated emission reductions.

Table 1 Overview of Connections under the PoA

Service Provider	Total Connections	Power Consumed (kWh)	Resulting Emission Reductions (tCO2e)
UMEME	53,353	12,387,596	16,821
KRECS	1,587	388,908	500
BECS	936	149,949	281
PACMECS	736	94,068	226
KIL	4,045	1,532,965	2,430
Total	60,657		

The SPs track the number of connections made in an electronic database. End-user information, meter number, and GPS coordinates (when available) are recorded in the system and reported to the CME.

Specific CPA Types B and C have not been included under the PoA to date.

B.2. Post-registration changes to PoA**B.2.1. Corrections**

To date the following post-registration changes have been made to the generic CPA and PoA:

The monitoring plan has been added to generic CPA Type A at the time of the first verification of the first CPA.

Revisions have been made to various sections of the design document as the document was updated to the latest template. From Version 3.0 to Version 8.1.

B.2.2. Inclusion of monitoring plan

There is a post-registration change to include a monitoring plan for generic CPA Type A only into the PoA-DD. The post-registration change is being submitted with this monitoring report.

PoA-DD Version Number: 6.0

PoA-DD Completion Date: 13/12/2017

DOE Validation Report Date: DD/MM/YYYY

B.2.3. Permanent changes to the registered monitoring plan, or permanent deviation of monitoring from the applied methodologies, standardized baselines, or other applied standards or tools

There are no permanent changes to the registered monitoring plan, or permanent deviation of monitoring from the applied methodologies, standardized baseline, or other applies standards or tools.

B.2.4. Changes to programme design

To date the following changes have been made to the programmed design.

The size limit for all CPA types under the PoA was revised to reflect Methodological Tool 19 Version 7 *Demonstration of additionality of microscale project activities* in the eligibility criteria.

The boundary type A CPAs was originally specified as covering a single service territory within the PoA boundary. As the restriction on CPA size limits has been revised to apply either at the CPA level or at the CPA unit level, the boundary of a type A CPA was revised to cover one or more service territories in the PoA boundary. The boundary of CPAs Type B and C were revised from 2 years to 5 years of technologies implemented since the start date.

PART II Monitoring of CPAs

Title: Accelerating Electrification through Grid Extension and off-grid electrification in Rural Areas of Uganda CPA 1

Reference Number: 10186-0001

SECTION C. Implementation of CPAs

C.1. Description of implemented CPAs

The CPA expanded access to electricity in the various service territories of Uganda through extensions of existing grids to increase access to electricity within the CPA boundaries.

The Government has articulated the “Uganda Vision 2040” that lays out broad policy directives and sets out a target of increasing access to electricity to 80 per cent by 2040. The First Rural Electrification Strategy and Plan (RESP-1) set the target of electrification rate in rural area from 1% in 2001 to 10% in 2010. However, the implementation of RESP-1 has been slow-paced. The rural access to electricity as of mid 2013 is reported to be around 7%²⁰.

The CPA increased access to electricity within the CPA boundary through grid extension, i.e. connecting households and institutions/SMEs to the national grid, who were not connected prior to the implementation of the project activity. The PoA implements these two technology types through the following methodologies:

- AMS-III.BB Version 2 Electrification of Communities Through Grid Extension or Construction of New Mini-Grids

The CPA covered the extension of the national grid with the goal of electrifying communities who prior to the project activity did not have access to the national grid. The first connection under the CPA was made on 27/06/2015 and the total number of connections to date under the CPAs is 4,045.²¹ The CME operated the CPA under the PoA. For the CPA, the CPA Implementer and CME are the same entity. The CME has done the following under the CPA:

- Manage the extension of the national grid and connection of households and institutions to the national grid, as implemented by Service Providers governing connections to the national grid in the service territory, by setting connection targets and designating regions of focus within the geographic boundary
- Collect and aggregate the information required for monitoring of the CPA and liaise with the CDM EB during the lifetime of the CPA
- Disperse connection materials to the Service Provider in the CPA boundary in this case Kilembe Investments Limited
- Communicate with households and SMEs/Institutions connected under the project activity during the life of the project concerning monitoring of the activity

The CPA covers one service territory managed by Kilembe Investment Trust (KIL). This Service Provider has progressively engaged in commercial distribution and sale of grid electricity as a Licensee by the Electricity Regulatory Authority. The Service Provider purchases the energy from Uganda Electricity Transmission Company Limited (UETCL) and sell to the end consumer at a tariff determined by the Electricity Regulatory Authority.

The Service Provider uses the prepayment system with some under the card prepayment system and others have keypad-prepaid meters. The Service Provider records a date of connection for every customer in its database. Only customers with a connection date after the start date of the CPA will be included in the monitoring of the CPA for the purpose of determining the emissions reductions achieved.

The connection of the consumers was made possible through extension of the grid as follows:

1. Medium Voltage 33kV Power lines
188 km of three-phase 33 kV overhead power line comprising of 50/100 mm² AAAC

²⁰ Uganda Bureau of Statistics. Uganda Rural Electrification Survey 2012. December 2013. Page 20.

²¹ Emission Reduction Worksheet for MR 1.xls

conductors, treated wooden poles and pole hardware accessories as per BS 1320 standard as well as pole mounted transformer sub-stations.

2. Low Voltage Distribution System Network
166.35 km of 415/240V low voltage distribution lines comprising of 50 mm² AAAC conductors, treated wooden poles and hardware accessories as per BS 1320 standard.

The purpose of the CPAs is to provide access to electricity to households in the CPA boundaries through grid connection to a national/regional grid. Carbon revenues earned under the CPAs is used to:

- Finance grid connections; and
- Build capacity for the provision of the supported technologies/measures within the CPA boundary; and
- Educate consumers and increase awareness of the availability and proper use of the technologies/measures to be implemented under the CPA.

The following diagram shows the different monitoring points for the CPA.





Figure 1 Monitoring Points of the CPA

The emission reduction calculations are based on the aggregated data from Monitoring Point 1. The consumption of each end-user can be validated from the billing records of the Service Provider in the Service Provider's electronic accounting system (Monitoring Point 2). The end-user information and meter numbers can in turn be validated by the technicians information, recorded at the time of installation and housed at the Service Provider.

C.2. Location of CPAs

The boundary of CPA 10186-0001 is the Western Service Territory of Uganda. The Western Service Territory is shown in the image below.



The image above shows the country of Uganda and the different service territories. The Western Service Territory is labelled in lilac.

C.3. Post-registration changes to CPAs

C.3.1. Temporary deviations from the monitoring plans in the included CPA-DDs, applied methodologies or standardized baselines

There are no temporary deviations from the monitoring plans in the included CPA-DD, applied methodologies or standardized baselines during this monitoring period, the CPA covered in this monitoring report.

C.3.2. Corrections

To date the following post-registration changes have been made to CPA 10186-0001:

The size limit for the CPA has been revised to reflect changes at the PoA level and references Methodological Tool 19 Version 7 *Demonstration of additionality of microscale project activities*. In addition, the boundary of a Type A CPA was revised to cover one or more service territories at the PoA level. The specific CPA only covers one service territory as at the time of registration.

The monitoring plan and guidance on sampling has been added to the CPA at the time of the first verification.

Revisions have been made to various sections of the design document as the document was updated to the latest template. From Version 4.0 to Version 8.1.

C.3.3. Changes to the start date of the crediting period

There are no changes to the start date of the crediting period fixed at the inclusion of the CPA covered in this monitoring report.

C.3.4. Inclusion of monitoring plan

There have been post-registration changes to include a monitoring plan into the CPA-DD, for which the delayed submission of the monitoring plan was chosen by the CME at the time of inclusion of the CPA.

Changes that have been notified to the secretariat from the period prior to this monitoring period:

None.

Changes that have been notified to the secretariat as applicable from this monitoring period:

For CPA 10186-0001, the changes are summarized as:

The monitoring plan and guidance on sampling has been added to the CPA at the time of the first verification.

Revisions have been made to various sections of the design document as the document was updated to the latest template. From Version 4.0 to Version 8.1.

C.3.5. Permanent changes to the included monitoring plans, or permanent deviation of monitoring from the applied methodologies, standardized baselines, or other applied standards or tools

There are no permanent changes to the monitoring plans included in the CPA-DD, or permanent deviation of monitoring from the applied methodologies, or standardized baseline, or other applied standards or tools for the CPA covered in this monitoring report.

C.3.6. Changes to project design

To date, the following changes have been made to the project design. The size limit for the CPA has been revised to reflect changes at the PoA level and references Methodological Tool 19 Version 7 *Demonstration of additionality of microscale project activities*. In addition, the boundary of a Type A CPA was revised to cover one or more service territories at the PoA level. The specific CPA only covers one service territory as at the time of registration.


SECTION D. Description of monitoring system of CPAs

The information collected for the CPA is the following:

Information	Source		Required for
GPS Coordinates the Connected User / Meter Serial Number	Service Records	Provider	Methodology Eligibility
Connection Date	Service Records	Provider	Parameter Determination
End-User Name	Service Records	Provider	Sampling
End-User Contact Number	Service Records	Provider	Sampling
End-User Type (Household/SME)	Service Records	Provider	Methodology Eligibility

The GPS coordinates of each household or SME/institution and/or meter serial number under the CPA is recorded to ensure the connection is unique. End-users without GPS coordinates or meter numbers cannot be counted under the CPA during monitoring. In addition, the type of end-user needs to be tracked (household or SME/institution) as the methodology requires at least 75 percent of the end-users to be households.

The information flow diagram for Type A CPAs is shown below.



The emission reductions under CPA is determined through the following equations.

$$ER_y = BE_y - PE_y - LE_y$$

Where

ER_y Emission reductions in year y (tCO₂e/y)

BE_y Baseline emission in year y (tCO₂e/y)

PE_y Project emissions in year y (tCO₂e/y)

LE_y Leakage emissions in year y (tCO₂e/y)

Under the CPAs both project emissions are baseline emissions are determined. Leakage emissions are considered zero. Baseline emissions are calculated as per the equations below.

$$BE_y = BE_{55,y} + BE_{250,y} + BE_{250 plus,y}$$

Where

BE_y Baseline emissions in the year y ; tCO₂

$BE_{55,y}$ Aggregate baseline emissions for facilities that consumed equal to or less than 55 kWh of renewable electricity from project renewable electricity systems in year y ; tCO₂

$BE_{250,y}$ Aggregate baseline emissions for facilities that consumed more than 55 kWh but equal to or less than 250 kWh of renewable electricity from project renewable electricity systems in year y ; tCO₂

$BE_{250 plus,y}$ Aggregate baseline emissions for facilities that consumed greater than 250 kWh of renewable electricity from project renewable electricity systems in year y ; tCO₂

As in the equation above, there are different tiers of energy consumption under the methodology ranging from 0 – 55 kWh, 55 – 250 kWh, and greater than 250 kWh. Each tier has an emission factor. The emission factors are 6.8, 1.3, and 1.0 (t CO₂e per MWh), respectively.

The total electricity purchased during the monitoring period is used to determine the tier within which the end-user. The electricity recorded through the pre-paid meters by each end-user the monitoring period is taken from the accounts of the service provider, which shows the total units purchased during the monitoring period. Electricity consumption for each consumer is the summation of the pre-paid electricity purchased during the monitoring period, excluding the last purchase during the monitoring period but including the last purchase of the previous monitoring period.

The emission reductions for each tier are calculated as follows:

$$BE_{55,y} = \sum_x EG_{x,y} * EF_{CO2,55}$$

Where

$EG_{x,y}$ Electricity delivered by project renewable electricity generation system to facility x , where the electricity delivered to that facility is equal to or less than 55 kWh in year y ; MWh

$EF_{CO2,55}$ 6.8 tCO₂/MWh

$$BE_{250,y} = \sum_z ((EG_{z,y} - 0.055) * EF_{CO2,250} + C)$$

Where

$EG_{z,y}$ Electricity delivered by project renewable electricity generation system to facility z in year y , where the electricity delivered to the facility is more than 55 kWh but equal to or less than 250 kWh in year y ; MWh

$EF_{CO2,250}$ 1.3 tCO₂/MWh

x Facility supplied with renewable electricity from operating project renewable electricity generation systems consuming more than 55 kWh but equal to or less than 250 kWh in year y

C 0.374 (tCO₂), a constant calculated as (0.055 MWh x 6.8 tCO₂/MWh)

$$BE_{250 plus,y} = \sum_w ((EG_{w,y} - 0.250) * EF_{CO2,250 plus} + D)$$

Where

$EG_{w,y}$ Electricity delivered by project renewable electricity generation system to facility w in year y such that the electricity delivered to the facility is more than 250 kWh in year y ; MWh

$EF_{CO2,250 plus}$ 1.0 tCO₂/MWh
2.0

w Facility supplied with renewable electricity from operating project renewable electricity generation systems consuming more than 250 kWh in year y

D 0.6275 (tCO₂), a constant calculated as (0.055 MWh x 6.8 tCO₂/MWh + 0.195 MWh x 1.3 tCO₂/MWh)

The purchase of electricity through the prepaid meter is deemed evidence of functionality of the connection. Connections without a purchase of electricity in the past six months are deemed inactive and not included in monitoring.

Project emissions are calculated as the total electricity consumed by all end-users under the CPA, multiplied by the grid emission factor for the national grid of Uganda. The number is adjusted to account for transmission and distribution losses. The emission factor for the national grid is 0.513

tCO₂ per MWh. The transmission and distribution losses are equal to 10 per cent, as per the methodology.

$$PE_y = (ED_{tot,y} * EF_{grid,CO_2,y}) \div (1 - TL_{grid})$$

Where

$ED_{tot,y}$ Total electricity delivered to all new and existing consumers (MWh)

$EF_{grid,CO_2,y}$ Emission factor of the project electricity system in year y (tCO₂/MWh)

TL_{grid} Transmission and distribution losses in the project activity electricity system supplying the project activity (%)

SECTION E. Data and parameters

E.1. Data and parameters fixed ex ante

(This section is intentionally blank.)

Data / Parameter:	
Data unit:	
Description:	
Source of data:	
Value(s) applied:	
Choice of data or Measurement methods and procedures:	
Purpose of data	
Additional comment:	

E.2. Data and parameters monitored

Data/Parameter	EC _{T1M,j,y}
Unit	MWh
Description	Electricity metered at Type I-M consumers <i>j</i>
Measured/calculated/default	Sum of all recorded purchases during the monitoring period as indicated in paragraph 14 of the methodology
Source of data	-
Value(s) of monitored parameter	Consumption values for the monitoring period are shown in the emission reduction calculation worksheet ²²
Monitoring equipment	Electricity Meters and electronic billing system
Measuring/reading/recording frequency	All purchases throughout the monitoring period are recorded
Calculation method (if applicable)	Summation of purchases in the monitoring period

²² Emission Reduction Worksheet for CPA 1.xls

QA/QC procedures	
Purpose of data/parameter	Determination of baseline and project emissions
Additional comments	

Data/Parameter	$EC_{T2,i,y}$
Unit	MWh
Description	Electricity metered at Type II consumers <i>i</i>
Measured/calculated/default	Sum of all recorded purchases during the monitoring period as indicated in paragraph 14 of the methodology
Source of data	-
Value(s) of monitored parameter	Consumption values for the monitoring period are shown in the emission reduction calculation worksheet ²³
Monitoring equipment	Electricity Meters and electronic billing system
Measuring/reading/recording frequency	All purchases throughout the monitoring period are recorded
Calculation method (if applicable)	Summation of purchases in the monitoring period
QA/QC procedures	
Purpose of data/parameter	Determination of baseline and project emissions
Additional comments	

Data/Parameter	f_{HH}
Unit	Fraction
Description	The fraction of end-users (by number) under the CPA that are households
Measured/calculated/default	Calculated
Source of data	Electronic database maintained by CME
Value(s) of monitored parameter	0.98
Monitoring equipment	N/A
Measuring/reading/recording frequency	Annually
Calculation method (if applicable)	The designation of the end user is determined at the time of installation of the solar power system. Each end-user is designated as either a household or a SME/Institution as shown in the monitoring plan. The total number of end users designated as households divided by the total number of end users gives the value of the parameter
QA/QC procedures	
Purpose of data/parameter	Eligibility
Additional comments	

Data/Parameter	LE_y
Unit	tCO ₂ /y
Description	Leakage in the project scenario in year <i>y</i>

²³ Emission Reduction Worksheet for MR 1.xls

Measured/calculated/default	Calculated
Source of data	Electronic database maintained by CME
Value(s) of monitored parameter	0.00
Monitoring equipment	Records from Service Provider
Measuring/reading/recording frequency	Annually
Calculation method (if applicable)	Leakage on account of construction of new transmission/distribution lines shall be calculated using the method indicated in baseline and monitoring methodology AM0045. If the estimate leakage is within 5% of the estimated emission reductions of the CPA in year y, then leakage may be neglected.
QA/QC procedures	Transparent data analysis and reporting
Purpose of data/parameter	Determination of Leakage
Additional comments	

E.3. Implementation of sampling plan

No parameters were determined using sampling.

SECTION F. Calculation of emission reductions or net anthropogenic removals

F.1. Calculation of baseline emissions or baseline net removals

The monitoring period covers. from 28/08/2015 through 03/05/2017. As the emission factor for each end-user is based on their annual consumption level, the baseline emissions are determined for each end-user for each 12-month period, as shown in the emission reduction calculation worksheet.

Baseline emissions are calculated as follows:

$$BE_y = BE_{T1NM,y} + BE_{T1M,y} + BE_{T2,y} + BE_{exist,y}$$

Where

$BE_{T1NM,y}$ Baseline emissions for Type I-NM consumers in year y (tCO₂)

$BE_{T1M,y}$ Baseline emissions for Type I-M consumers in year y (tCO₂)

$BE_{T2,y}$ Baseline emission for Type II consumers in year y (tCO₂)

$BE_{exist,y}$ Baseline emissions of existing consumers i.e. baseline emissions from displacement of electricity from an existing mini-grid (tCO₂)

For the CPA, Option 2 under paragraph 14 of the methodology is used to determine baseline emissions.

Under the CPA, all end-users will be metered. It follows $BE_{T1NM,y}$ is equal to zero.

All end-users under the project activity will be metered through prepaid devices. As such there are no existing users metered under the project activity. It follows that $BE_{exist,y}$ is equal to zero.

Baseline emissions for Type I consumers are calculated as follows:

$$BE_{T1M,y} = \sum_{j=1}^{M_y} EC_{T1M,j,y} \times EF_{CO2,T1M}$$

Where

$EC_{T1M,y}$ Annual electricity consumption for all Type I-M consumers j in year y (MWh)

M_y Number of Type I-M consumers in year y

j Type I-M consumer ($j = 1, 2, 3, \dots$)

$EF_{CO2,T1M}$ Emission factor for Type I-M consumers:

- If the electricity consumed during year y is equal to or less than 0.055 MWh/y, then use a default value of 6.8
- If the electricity consumed during year y is less than or equal to 0.25 MWh/y but greater than 0.055 MWh/y then for the portion up to and including 0.055 MWh/y, use a default value of 6.8 and for the portion greater than 0.055 MWh/y, use a default value of 1.3.
- If the electricity consumed during year y is greater than 0.25 MWh/y but less than 0.500 MWh/y then for the portion up to and including 0.055 MWh/y, use a default value of 6.8, for the portion greater than 0.055 MWh/y and less than 0.25 MWh/y use a default value of 1.3, and for the portion greater than 0.25 MWh/y use a default value of 1.0.
- If the electricity consumed is greater than 0.500 MWh/y then use a default value of 1.0 for the entire portion.

Baseline emissions for Type II consumers are calculated as follows:

$$BE_{T2,y} = \sum_{i=1}^{N_y} EC_{T2,i,y} * EF_{CO2,T2}$$

Where

$EC_{T2,i,y}$ Metered annual electricity consumption of Type II consumer i in year y (MWh)

$EF_{CO2,T2}$ 1.0 (tCO₂/MWh)

N_y Type II consumer ($i = 1, 2, 3, \dots$)

Total baseline emissions for the 4,045 end-users under the CPA are determined for each end-user through summation of the annual usage through billing records and then multiplied by the corresponding emission factor. The summation is shown in the emission reduction worksheet.²⁴

$$BE_y = 2,509 \text{ tCO}_2\text{e}$$

F.2. Calculation of project emissions or actual net removals

Project emissions under a generic CPA are calculated as follows:

²⁴ Emission Reduction Worksheet for MR 1

$$PE_y = (ED_{tot,y} * EF_{grid,CO_2,y}) \div (1 - TL_{grid})$$

Where

$ED_{tot,y}$ Total electricity delivered to all new and existing consumers (MWh)

$EF_{grid,CO_2,y}$ Emission factor of the project electricity system in year y (tCO₂/MWh)

TL_{grid} Transmission and distribution losses in the project activity electricity system supplying the project activity (%)

Project emissions are the summation of the consumption for each end-user multiplied by the national grid emission factor of Uganda.

$$PE_y = (1,533 \text{ MWh} * 0.513 \text{ tCO}_2\text{e/MWh}) * (1-0.1)$$

$$PE_y = 708 \text{ tCO}_2\text{e}$$

F.3. Calculation of leakage emissions

Leakage is assessed following baseline and monitoring methodology AM0045 “Grid connection of isolated electricity systems” where leakage is defined as follows:

$$LE_y = A_{def} * L_c$$

Where

A_{def} is the area of land deforested in hectares.

L_c is the carbon stock per unit area in tonnes of CO₂ per hectare.

The CPA Implementer of a generic CPA under the PoA will track leakage emissions arising due to transmission lines construction. All transmission lines constructed during the monitoring period in question within the CPA boundary will be reported to estimate the leakage emissions from this source in conjunction with credible literature on the carbon stock in the region.

The CPA covers last mile grid extension only, e.g. the extension of the transmission line from existing power lines to households. There is no clearance of forest or other biomass that is greater than 5% of the project emissions under the CPA. Therefore leakage is considered 0.

F.4. Calculation of emission reductions or net anthropogenic removals

CPA UNFCCC reference number	Baseline GHG emissions or baseline net GHG removals (t CO ₂ e)	Project GHG emissions or actual net GHG removals (t CO ₂ e)	Leakage GHG emissions (t CO ₂ e)	GHG emission reductions or net anthropogenic GHG removals (t CO ₂ e)		
				Before 01/01/2013	From 01/01/2013	Total amount
10186-0001	2,050	532	0	0	1,518	1,518
Total	2,050	532	0	0	1,518	1,518

F.5. Comparison of emission reductions or net anthropogenic removals achieved with estimates in the included CPA-DDs

CPA UNFCCC reference number	Amount achieved during this monitoring period (t CO ₂ e)	Amount estimated ex ante (t CO ₂ e)
10186-0001	1,518	12,833
Total	1,518	12,833

F.6. Remarks on increase in achieved emission reductions

The monitoring period covers from 28/08/2015 through 03/05/2017. The ex-ante emissions for the CPA were estimated as follows:

2015 – 3,413 tCO₂e
 2016 – 7,108 tCO₂e
 2017 – 13,761 tCO₂e

Multiplying the respective years by the fraction of the year covered by the monitoring period yields the following:

2015: 3,413 tCO₂e * (4/12) = 1,138 tCO₂e
 2016: 7,108 tCO₂e * (12/12) = 7,108 tCO₂e
 2017: 13,761 tCO₂e * (4/12) = 4,587 tCO₂e

1,138 tCO₂e + 7,108 tCO₂e + 4,587 tCO₂e = 12,833 tCO₂e

The amount achieved during the monitoring period is 1,518 tCO₂e. The discrepancy is due to the lower amount of connections active during the time period than previously expected. The ex-ante estimate assumed 16,000 connections in 2017. While the monitoring period only covers 4,045.

- - - - -

Document information

Version	Date	Description
02.0	7 June 2017	Revision to: <ul style="list-style-type: none">• Ensure consistency with version 01.0 of the “CDM project standard for programmes of activities (CDM-EB93-A07-STAN);• Make editorial improvements.
01.0	1 April 2015	Initial publication.
Decision Class: Regulatory Document Type: Form Business Function: Issuance Keywords: monitoring report, programme of activities		