



# BANNARI AMMAN SUGARS LIMITED

Factory : Post Box No. 16 Sathyamangalam 638 401 Erode Dt. Tamil Nadu  
Phone : 04295-20363, 20387 Grams : AMMAN SUGAR Fax : 04295-20695 Email : bassathy@vsnl.com

BA/ ZGP/ 11103/ 4891

The Superintending Engineer  
Gobi Electricity Distribution Circle  
Pathi Vilas Road  
Gobichettipalayam 638 452

Dear sir

Sub: Electricity - HT S.C. No.103 - 20MW Co-generation Plant  
Stoppage - Regarding

we wish to state that we have started our 20-MW Co-generation plant at our sugar unit on 26.8.2002 at 10-30 AM and started exporting power to TNEB grid. The machine tripped at 8-20 PM on the same day to low vacuum on Condenser and the machine was resynchronised with grid at 9-10 PM on the same day.

Again the machine was stopped on 27.8.2002 at 2-20 PM for linking the sugar plant with Co generation plant and would be restarted on 4.9.2002.

This is for your kind information.

Thanking you

Yours faithfully  
For BANNARI AMMAN SUGARS LTD

*P Dhawala*  
VICE PRESIDENT

cc: Chief Engineer, TNEB, Erode Region, Erode  
Executive Engineer, O&M, SENC, Sathy-1  
Asst. Executive Engineer, O&M, East Sathy  
Assistant Engineer, TNEB, Periakodivery

*Dr*

TAMIL NADU ELECTRICITY BOARD  
PERIYAR ELECTRICITY DISTRIBUTION CIRCLE

H.T. METER READING CARD

DISPLAY LEGEND-17

H.T. SC No. 103

Date of supply 26.8.2002

Tariff

Consumer Name & Address: M/s Bannari Amman Sugars Limited  
Alathukombai  
Sathyamangalam 638 401  
Erode District

CONNECTED LOAD

Sanctioned Demand 400-KVA Industrial ADD. Demand. 950 kVA *appealed on 13-9-02*  
*26.8.02*

Consumer's Transformer No. JN 8028/1  
VOLTAMP

Capacity: 25000-KVA

Metering on EHT side

H.T. Metering Set details: P.T. Ratio 110-KV/110-V  
CT Ratio available ~~150/5A~~ Adopted 150/5A ✓  
*200-150-100-50-25/5A*

Meter Name Plate Details

Make: DUKEARNICS Type

Sl.No.

Meter Rent

Voltage Ratio: -/110V CT Ratio: /5A

Meter Constant

M.F. for Energy: 30000

M.F. for M.D. 30000

*28/8/02*  
Signature of A.E.

Signature of A.E.E.

*28.8.02*  
Signature of E.E.

=====

H.T. S.C. NO.103 M/S BANNARI AMMAN SUGARS LIMITED  
CO-GENERATION - MONTHLY READING FOR THE MONTH OF AUGUST 2002.

28-08-2002

S.No.	IMPORT	I.R. on 26.8.2002	F.R. on 28.8.2002	Difference	M.F.	Consumption
01	KWH	9.97	11.38	1.41	30000	42,300-UNITS
02	KVARH (LAG)	7.03	7.16	0.13	30000	3,900-UNITS
03	KVARH (LED)	0.44	0.55	0.11	30000	3,300-UNITS
04	KVAH	13.85	15.28	1.43	30000	42,900-UNITS
EXPORT						
01	KWH	0.61	0.62	0.01	30000	300-UNITS
02	KVARH	0.12	0.14	0.02	30000	600-UNITS
03	KVARH (LED)	0.00	0.00	0.00		
04	KVAH	0.64	0.66	0.02	30000	600-UNITS

*[Signature]*  
28/8/02  
ASST. ENGINEER  
RURAL/NORTH, SATHY

*[Signature]*  
28.8.02  
EXECUTIVE ENGINEER  
GEDC-SATHY

*[Signature]*  
28/8/02  
CONSUMER'S SIGNATURE  
Chief Engineer (Grids)


H.T. S.C. NO.103 M/S BANNARI AMMAN SUGARS, LIMITED  
CO-GENERATION - MONTHLY READING FOR THE MONTH OF AUGUST 2002

28-08-2002

S.No.	IMPORT	I.R. on 26.8.2002	F.R. on 28.8.2002	Difference	M.F.	Resultant M.D.
01	KW	00	0.07	0.07	30000	2,100-KW
02	KVA	00	0.08	0.08	30000	2,400-KVA
03	KVAR (LAG)	00	0.03	0.03	30000	,900-KVAR
04	KVAR (LED)	00	0.00	---	---	---
EXPORT						
01	KW	00	0.01	0.01	30000	300-KW
02	KVA	00	0.01	0.01	30000	300-KVA
03	KVAR (LED)	00	0.02	0.02	30000	600-KVAR
04	KVAR (LAG)	00	0.01	0.01	30000	300-KVAR

  
ASST. ENGINEER  
RURAL/NORTH, SATHY

  
EXECUTIVE ENGINEER  
GEDC-SATHY

  
CONSUMER'S SIGNATURE  
Chandrasekhar (K. S. S. S. S.)

=====