

M.L. 61

DODSON - LINDBLOM HYDRO POWER PVT. LTD.

1 X 12 MW POWER HOUSE NO. 1, BHANDARDARA

MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF MARCH - 2009

DATE : 31-03-2009
TIME : 12.49

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION: 100 / 1, class 0.2

PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	258236	258050
	2	2	Total kVARh - Q1	25401	26511
	3	3	Total kVARh - Q4	48	46
	4	4	Total kVAh - Q1+Q4	259832	259817
	5	5	Rate C Max kVA - Q1 + 4	10.97	10.96
	6	6	Average Power Factor kWh - Del	0.995	0.995
	7	7	Total kWh - Received	115	97
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	63	52
	10	10	Total kVAh - Q2+3	135	114
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	63.68	63.69
	*	14	Phase B Voltage	63.91	63.85
	*	15	Phase C Voltage	63.36	63.33
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	31.03.09	31.03.09
	20	20	Present Time	12.49	12.48

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	63.00	63.68	Vrn	62.00	63.69
Vyn	63.00	63.91	Vyn	62.00	63.85
Vbn	62.00	63.36	Vbn	62.00	63.33
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead seal
Meter Box :-		D0486006	Meter Box :-		D0486007
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- --- ---

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
DATE 31.03.09

B. D. Fulpagar
31.03.09

A. V. Naik
31.03.09

S. S. Titare
31.03.09

K. S. Thakur
31.03.09

P. A. Kothmire
31.03.09

PLANT MANAGER
DLHPPL, BHANDARDARA

Exec. Engineer
B.H.E. (O&M) Dn. Nashik Road

Exec. Engr. (Testing)
MSEDCL, Nashik

SECT. OFFICER M.S.E.T.C.L. Nashik Road

B.H.E. SECT.
Bhandardara

Inward No. 13852
Date 01/04/2009
Time 10:30 AM
File No. M2-01
Sign

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12 MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 31-03-2009

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	24.12.2008	23.12.2008	23.12.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 28.02.2009 TO 31.03.2009

METER READING TAKEN ON DATE :- 31.03.2009 AT 12.49 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	315610890	258236	258050
KWH PAST	312768330	255913	255729
DIFFERENCE	2842560	2323	2321
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	2842560	2787600	2785200
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	23475750	23016000	23002800
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	26318310	25803600	25788000
POWER FACTOR	0.986	0.995	0.995

FOR DLHPPL

NAME R. V. Jadhav
DATE 31.03.09

PLANT MANAGER
DLHPPL, BHANDARDARA

FOR GOMWRD

B. D. Fulpagar
31.03.09

SECT. OFFICER
B.H.E. SECT.

Chandradatta

FOR MSETCL

A. V. Naik
31.03.09

.Exc. Engineer
E.H.V. (O&M) Div.
M.S.E.T.C.L. Nashik Road

S. S. Titare
31.03.09

Exc. Engr. (Test)
Nashik Road

FOR MSEDC

K. S. Thakur
31.03.09

P. A. Kothmire
31.03.09

For Engr. (Test)
M.S.E.T.C.L. Nashik Road

For Engr. (Test)
M.S.E.T.C.L. Nashik Road

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12 MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE :-

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
---	---	---	---	---


2) DUE TO DISPATCH INSTRUCTIONS :-

NIL

3) DUE TO FORCE MAJEURE :-

NIL

FOR DLHPPL




NAME:- R. V. Jadhav

DATE:- 31.03.2009

PLANT MANAGER
DLHPPL BHANDARDARA

FOR MSETCL



NAME:- A. V. Naik

DATE:- 31.03.2009

.Exe.Engineer
E.H.V.(O&M)Dn.
M.S.E.T.C.L. Nashik Road

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK :-

NIL

2) DUE TO POLITICAL FORCE MAJEURE :-

NIL

3) DUE TO NON RELEASE OF WATER TO MDDL :-

NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER

THROUGH P. H. NO. 1 IN DEPENDABLE YEAR. :-

NIL

a) WATER FLOW METER READING RECORDED
ON 31.03.09 AT 12.49 HRS. :-

438.20 MCM

b) WATER RELEASED DURING THIS MONTH :-

18.20 MCM

c) CUMULATIVE WATER RELEASED UPTO DATE
FROM 01.10.2008 FOR WATER YEAR 2008-09 :-


95.60 MCM

d) CUMULATIVE WATER RELEASED IN WATER
YEAR 2008-09 :-

154.10 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL



NAME:- R. V. Jadhav

DATE:- 31.03.2009

PLANT MANAGER
DLHPPL BHANDARDARA

FOR GOMWRD



NAME:- B. D. Fulpagar

DATE:- 31.03.2009

SECT. OFFICER
B.H.E. SECT.
Bhandardara

DODSON - LINDBLOM HYDRO POWER PVT. LTD.
1 X 12MW POWER HOUSE NO. 1, BHANDARDARA
MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF FEBRUARY - 2009

DATE : 28.02.2009
 TIME : 12.22

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION: 100 / 1, class 0.2 **PT SPECIFICATION:** 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	255913	255729
	2	2	Total kVARh - Q1	25176	26284
	3	3	Total kVARh - Q4	48	46
	4	4	Total kVAh - Q1+Q4	257498	257485
	5	5	Rate C Max kVA - Q1 + 4	11.32	11.31
	6	6	Average Power Factor kWh - Del	0.995	0.995
	7	7	Total kWh - Received	115	97
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	63	52
	10	10	Total kVAh - Q2+3	135	114
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	66.54	66.43
	*	14	Phase B Voltage	66.55	66.39
	*	15	Phase C Voltage	65.98	65.88
	*	16	Phase A Current	0.54	0.54
	*	17	Phase B Current	0.56	0.56
	*	18	Phase C Current	0.55	0.55
	19	19	Present Date	28.02.09	28.02.09
	20	20	Present Time	12.22	12.24

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.54	0.54	Ir	0.54	0.54
Iy	0.56	0.56	Iy	0.56	0.56
Ib	0.55	0.55	Ib	0.55	0.55
Vrn	65.00	66.54	Vrn	65.00	66.43
Vyn	65.00	66.55	Vyn	65.00	66.39
Vbn	64.00	65.98	Vbn	64.00	65.88
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead seal
Meter Box :-		D0485841	Meter Box :-		D0485842
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- --- ---

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
 DATE 28.02.09

B. D. Fulpagar
 28.02.09

P. G. Kandhare
 28.02.09

H. D. Ade
 28.02.09

P. A. Kothmire
 28.02.09

PLANT MANAGER
 DLHPPL, BHANDARDARA

SECT. OFFICER

Exe. Engineer

Ex. Engr. (Testing)
 M.S.E.D.C.L. Nashik -

D.H.E. SECT. M. S. E. T. Co. Ltd.

Bhandardara L.V. (O&M) Dn. Nasik Road

कार्यकारी अभियंता
 म.स.विद्युत परियोजना कॉ.म.स.प.
 स्याचणी विभाग, विद्युत भवन
 मांशेकरगड

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 28.02.2009

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	24.12.2008	23.12.2008	23.12.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 31.01.2009 TO 28.02.2009
METER READING TAKEN ON DATE :- 28.02.2009 AT 12.22 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	312768330	255913	255729
KWH PAST	310117060	253749	253566
DIFFERENCE	2651270	2164	2163
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	2651270	2596800	2595600
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	20824480	20419200	20407200
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	23475750	23016000	23002800
POWER FACTOR	0.987	0.995	0.995

FOR DLHPPL

NAME R. V. Jadhav
DATE 28.02.09

PLANT MANAGER
DLHPPL, BHANDARDARA

FOR GOMWRD

B. D. Fulpagar
28.02.09

SECT. OFFICER
S.N.E. SECT.
Bhandardara

FOR MSETCL

P. G. Kandhare
28.02.09

Exe. Engineer
M. S. E. T. Co. Ltd.

FOR MSEDCI

H. D. Ade
28.02.09

P. A. Kothmire
28.02.09

Ex. Engr. (Testing)
M. S. E. D. C. L. Nashik -

कार्यकारी अभियंता
म. रा. विद्युत परियोजना की मर्याद.
घाचणी न. म. विद्युत भवन
न. रा. वि. रा. ड.

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE :-

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
—	—	—	—	—
—	—	—	—	—
—	—	—	—	—

2) DUE TO DISPATCH INSTRUCTIONS :-

NIL

3) DUE TO FORCE MAJEURE :-

NIL

FOR DLHPPL

FOR MSETCL

NAME:- R. V. Jadhav

DATE:- 28.02.2009

PLANT MANAGER
DLHPPL, BHANDARDARA

NAME:- P. G. Kandhare

DATE:- 28.02.2009

Exec. Engineer
M. S. E. S. O. D. S. D.
E. H. V. (P. H. No. 1) Nashik Road

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK :-

NIL

2) DUE TO POLITICAL FORCE MAJEURE :-

NIL

3) DUE TO NON RELEASE OF WATER TO MDDL :-

NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER
THROUGH P. H. NO. 1 IN DEPENDABLE YEAR. :-

NIL

a) WATER FLOW METER READING RECORDED
ON 28.02.09 AT 12.22 HRS. :-

420.00 MCM

b) WATER RELEASED DURING THIS MONTH :-

16.30 MCM

c) CUMULATIVE WATER RELEASED UPTO DATE
FROM 01.10.2008 FOR WATER YEAR 2008-09 :-

77.40 MCM

d) CUMULATIVE WATER RELEASED IN WATER
YEAR 2008-09 :-

135.90 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

FOR GOMWRD

NAME:- R. V. Jadhav

DATE:- 28.02.2009

PLANT MANAGER
DLHPPL, BHANDARDARA

NAME:- B. D. Fulpagar

DATE:- 28.02.2009

SECT. OFFICER
P. H. E. SECT.
Bhandardara

DODSON - LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO. 1, BHANDARDARA

MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF JANUARY - 2009

DATE : 31.01.09
TIME : 14.10

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION 100 / 1, class 0.2 PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	253749	253566
	2	2	Total kVARh - Q1	24978	26083
	3	3	Total kVARh - Q4	47	46
	4	4	Total kVAh - Q1+Q4	255324	255312
	5	5	Rate C Max kVA - Q1 + 4	11.83	11.82
	6	6	Average Power Factor kWh - Del	0.996	0.996
	7	7	Total kWh - Received	115	97
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	63	52
	10	10	Total kVAh - Q2+3	135	114
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	65.78	65.96
	*	14	Phase B Voltage	65.46	65.81
	*	15	Phase C Voltage	65.62	65.63
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	31.01.09	31.01.09
	20	20	Present Time	14.10	14.08

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	65.71	65.78	Vrn	65.80	65.96
Vyn	65.50	65.46	Vyn	65.77	65.81
Vbn	65.63	65.62	Vbn	65.57	65.63
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead seal
Meter Box :-		D0485698	Meter Box :-		D0485699
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- ---

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav

B. D. Fulpagar

T. D. Wagh

H. D. Ade
31.01.09

K. S. Thakur
31.01.09

A. P. Rathod
31.01.09

DATE 31.01.09
ANT MANAGER
PL, BHANDARDARA

DATE 31.01.09
ANT MANAGER
PL, BHANDARDARA

.Exe.Engineer
E.H.V.(O&M)Dn.
M.S.E.T.C.L. Nashik Road

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

Executive Engineer
MSETCL, Testing Division,

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 31.01.09

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	24.12.2008	23.12.2008	23.12.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 31.12.2008 TO 31.01.2009
METER READING TAKEN ON DATE :- 31.01.2009 AT 14.10 Hrs.


	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	310117060	253749	253566
KWH PAST	304168320	248887	248707
DIFFERENCE	5948740	4862	4859
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	5948740	5834400	5830800
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	14875740	14584800	14576400
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	20824480	20419200	20407200
POWER FACTOR	0.988	0.996	0.996

FOR DLHPPL

FOR GOMWRD


FOR MSETCL


FOR MSEDCL



NAME R. V. Jadhav
DATE 31.01.09


B. D. Fulpagar
31.01.09


T. D. Wagh
31.01.09


H. D. Ade
31.01.09


K. S. Thakur
31.01.09


A. P. Rathod
31.01.09

PLANT MANAGER
DLHPPL, BHANDARDARA

SECT. OFFICER
B.H.E. SECT.
Bhandardara.

Exe. Engineer
E.H.V. (O&M) Dn.
M.S.E.T.C.L. Nashik Road

Executive Engineer
MSETCL., Testing Division,

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE :-

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		

2) DUE TO DISPATCH INSTRUCTIONS :-

NIL

3) DUE TO FORCE MAJEURE :-

NIL

FOR DLHPPL

NAME:- R. V. Jadhav

DATE:- 31.01.2009

PLANT MANAGER
DLHPPL, BHANDARDARA

FOR MSETCL

NAME:- T. D. Wagh

DATE:- 31.01.2009

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK :-

NIL

2) DUE TO POLITICAL FORCE MAJEURE :-

NIL

3) DUE TO NON RELEASE OF WATER TO MDDL :-

NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER THROUGH P. H. NO. 1 IN DEPENDABLE YEAR. :-

NIL

a) WATER FLOW METER READING RECORDED ON 31.01.08 AT 14.10 HRS. :-

403.70 MCM

b) WATER RELEASED DURING THIS MONTH :-

35.10 MCM

c) CUMULATIVE WATER RELEASED UPTO DATE FROM 01.10.2008 FOR WATER YEAR 2008-09 :-

61.10 MCM

d) CUMULATIVE WATER RELEASED IN WATER YEAR 2008-09 :-

119.60 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

NAME:- R. V. Jadhav

DATE:- 31.01.2009

PLANT MANAGER
DLHPPL, BHANDARDARA

FOR GOMWRD

NAME:- B. D. Fulpagar

DATE:- 31.01.2009

SECT. OFFICER
R.H.F. SECT.

DODSON - LINDBLOM HYDRO POWER PVT. LTD.
1 X 12MW POWER HOUSE NO. 1, BHANDARDARA
 MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF DECEMBER - 2008

DATE : 31.12.08
 TIME : 13.03

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION: 100 / 1, class 0.2

PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	248887	248707
	2	2	Total kVARh - Q1	24594	25693
	3	3	Total kVARh - Q4	47	46
	4	4	Total kVAh - Q1+Q4	250446	250436
	5	5	Rate C Max kVA - Q1 + 4	0.00	0.00
	6	6	Average Power Factor kWh - Del	1.000	1.000
	7	7	Total kWh - Received	115	97
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	63	52
	10	10	Total kVAh - Q2+3	135	114
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	64.79	64.45
	*	14	Phase B Voltage	65.08	64.58
	*	15	Phase C Voltage	64.64	64.32
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	31.12.08	31.12.08
	20	20	Present Time	13.03	13.07

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	63.00	64.79	Vrn	63.00	64.45
Vyn	64.00	65.08	Vyn	63.00	64.58
Vbn	63.00	64.64	Vbn	63.00	64.32
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead seal
Meter Box :-		D0485598	Meter Box :-		D0485599
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- --- ---

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
 DATE 31.12.08

B. D. Fulpagar
 31.12.08

B. D. Pedhekar
 31.12.08

S. S. Titare
 31.12.08

D. B. Daphane
 31.12.08

P. A. Kothmire
 31.12.08

PLANT MANAGER
 DLHPPL, BHANDARDARA

SECT. OFFICER
B.H.E. SECT.
 Bhandardara

Ex. Engr.
 Trans. (O&M) Dn. NSK

Executive Engineer
 MSETCL., Testing Division,
 Nashik Road

Ex. Engr. (Testing)
 M.S.E.D.C.L. Nashik -

Ex. Engr. (Testing)
 M.S.E.D.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 31.12.08

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	24.12.2008	23.12.2008	23.12.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 30.11.2008 TO 31.12.2008
METER READING TAKEN ON DATE :- 31.12.2008 AT 13.03 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	304168320	248887	248707
KWH PAST	302817330	247781	247602
DIFFERENCE	1350990	1106	1105
UNITS CONSUMED DURING TESTING	14430	15	14
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	1336560	1309200	1309200
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	13539180	13275600	13267200
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	14875740	14584800	14576400
POWER FACTOR	0.988	0.996	0.996

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSIEDCL

NAME R. V. Jadhav
DATE 31.12.08

PLANT MANAGER
DLHPPL, BHANDARDARA

B. D. Fulpagar
31.12.08

SECT. OFFICER
B.H.E. SECT.
Bhandardara

B. D. Pedhekar
31.12.08

S. S. Titare
31.12.08

Executive Engineer
MSETCL., Testing Division,
Nashik Road

D. B. Daphane
31.12.08

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

P. A. Kothmire
31.12.08

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
01-12-08	10:18	10:28	0.50	Due to fluctuations in 132 KV Grid parameters our Unit tripped on Negative Phase Sequence protection.
01-12-08	14:24	11:34		
01-12-08	17:40	17:50		

2) DUE TO DISPATCH INSTRUCTIONS

:- NIL

3) DUE TO FORCE MAJEURE

:- NIL

FOR DLHPPL

FOR MSETCL

NAME:- R. V. Jadhav

DATE:- 31.12.2008

PLANT MANAGER
DLHPPL, BHANDARDARA

NAME:- B. D. Pedhekar

DATE:- 31.12.2008

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK

:- NIL

2) DUE TO POLITICAL FORCE MAJEURE

:- NIL

3) DUE TO NON RELEASE OF WATER TO MDDL

:- NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER

THROUGH P. H. NO. 1 IN DEPENDABLE YEAR.

:- NIL

a) WATER FLOW METER READING RECORDED
ON 31.12.08 AT 13.03 HRS.

:- 368.60 MCM

b) WATER RELEASED DURING THIS MONTH

:- 07.60 MCM

c) CUMULATIVE WATER RELEASED UPTO
DATE FROM 01.10.2008 FOR WATER YEAR 2008-

:- 26.00 MCM

d) CUMULATIVE WATER RELEASED IN WATER
YEAR 2008-09

:- 84.50 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

NAME:- R. V. Jadhav

DATE:- 31.12.2008

PLANT MANAGER
DLHPPL, BHANDARDARA

FOR GOMWRD

NAME:- B. D. Fulpagar

DATE:- 31.12.2008

SECT. OFFICER
B.H.E. SECT.
Bhandardara

DODSON - LINDBLOM HYDRO POWER PVT. LTD.
1 X 12MW POWER HOUSE NO. 1, BHANDARDARA
 MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF NOVEMBER - 2008

DATE : 30.11.08
 TIME : 13.42

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION: 100 / 1, class 0.2

PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	247781	247602
	2	2	Total kVARh - Q1	24505	25603
	3	3	Total kVARh - Q4	46	45
	4	4	Total kVAh - Q1+Q4	249333	249324
	5	5	Rate C Max kVA - Q1 + 4	12.00	11.99
	6	6	Average Power Factor kWh - Del	0.997	0.997
	7	7	Total kWh - Received	100	82
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	55	44
	10	10	Total kVAh - Q2+3	118	97
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	65.28	65.23
	*	14	Phase B Voltage	65.34	65.27
	*	15	Phase C Voltage	65.02	64.77
	*	16	Phase A Current	0.59	0.59
	*	17	Phase B Current	0.61	0.62
	*	18	Phase C Current	0.61	0.61
	19	19	Present Date	30.11.08	30.11.08
	20	20	Present Time	13.42	13.44

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.59	0.59	Ir	0.59	0.59
Iy	0.61	0.61	Iy	0.62	0.62
Ib	0.61	0.61	Ib	0.60	0.61
Vrn	64.00	65.28	Vrn	64.00	65.23
Vyn	64.00	65.34	Vyn	64.00	65.27
Vbn	63.00	65.02	Vbn	63.00	64.77
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead Seal
Meter Box :-		D0485524	Meter Box :-		D0485525
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- ----

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
 DATE 30.11.08

B. D. Fulpagar
 30.11.08

B. D. Pedekar
 30.11.08

H. D. Ade
 30.11.08

P. A. Kothmire
 30.11.08

P. A. Kothmire
 30.11.08

शाखाधिकारी
 भंडारदारा जलविद्युत शाखा
 भंडारदारा, ता. अकोले

Executive Engineer
 TRANS. O&M DIVISION
 M S E T C L, NASHIK

Ex. Engr. (Testing)
 MSEDCL Nashik -

Ex. Engr. (Testing)
 MSEDCL Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 30.11.08

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	27.06.2008	26.06.2008	26.06.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 31.10.2008 TO 30.11.2008
METER READING TAKEN ON DATE :- 30.11.2008 AT 13.42 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	302817330	247781	247602
KWH PAST	300920410	246230	246052
DIFFERENCE	1896920	1551	1550
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	1896920	1861200	1860000
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	11642260	11414400	11407200
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	13539180	13275600	13267200
POWER FACTOR	0.988	0.997	0.997

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDC

NAME R. V. Jadhav
DATE 30.11.08

B. D. Fulpagar
30.11.08

B. D. Pedekar
30.11.08

H. D. Ade
30.11.08

D. B. Daphane
30.11.08

P. A. Kothmire
30.11.08

शाखाधिकारी

भंडारदरा जलविद्युत शाखा
भंडारदरा, ता. अकोले

Executive Engineer
TRANS. DIVISION
MSETCL, NASIK

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik

20/11/08
M.S.E.D.C.L. Nashik

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE :-

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		

2) DUE TO DISPATCH INSTRUCTIONS :-

NIL

3) DUE TO FORCE MAJEURE :-

NIL

FOR DLHPPL

FOR MSETCL

NAME:- R. V. Jadhav

DATE:- 30.11.2008

PLANT MANAGER
DLHPPL, B. D. ...

NAME:- B. D. Pedekar

DATE:- 30.11.2008

Executive Engineer
TRANS. & S.M. DIVISION
M S E T C L, NASIK

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK :-

NIL

2) DUE TO POLITICAL FORCE MAJEURE :-

NIL

3) DUE TO NON RELEASE OF WATER TO MDDL :-

NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER

THROUGH P. H. NO. 1 IN DEPENDABLE YEAR.

:- NIL

a) WATER FLOW METER READING RECORDED
ON 30.11.08 AT 13.42 HRS.

:- 361.00 MCM

b) WATER RELEASED DURING THIS MONTH

:- 10.70 MCM

c) CUMULATIVE WATER RELEASED UPTO
DATE FROM 01.10.2008 FOR WATER YEAR 2008-

:- 18.40 MCM

d) CUMULATIVE WATER RELEASED IN WATER
YEAR 2008-09

:- 76.90 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

FOR GOMWRD

NAME:- R. V. Jadhav

DATE:- 30.11.2008

PLANT MANAGER
DLHPPL, B. D. ...

NAME:- B. D. Fulpagar

DATE:- 30.11.2008

PLANT MANAGER
GOMWRD, B. D. ...

DODSON - LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO. 1, BHANDARDARA

MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF OCTOBER - 2008

DATE : 31.10.08
TIME : 13.04

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION 100 / 1, class 0.2

PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	246230	246052
	2	2	Total kVARh - Q1	24396	25492
	3	3	Total kVARh - Q4	46	45
	4	4	Total kVAh - Q1+Q4	247778	247770
	5	5	Rate C Max kVA - Q1 + 4	12.05	12.05
	6	6	Average Power Factor kWh - Del	0.997	0.997
	7	7	Total kWh - Received	100	82
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	55	44
	10	10	Total kVAh - Q2+3	118	97
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	63.55	63.47
	*	14	Phase B Voltage	63.32	63.45
	*	15	Phase C Voltage	63.37	63.30
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	31.10.08	31.10.08
	20	20	Present Time	13.04	13.06

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	62.00	63.55	Vrn	62.00	63.47
Vyn	62.00	63.32	Vyn	62.00	63.45
Vbn	62.00	63.37	Vbn	62.00	63.30
Seals			Seals		
MTC :-	Lead Seal		MTC :-	Lead seal	
TTB :-	Lead Seal		TTB :-	Lead Seal	
Meter Box :-	D0485418		Meter Box :-	D0485419	
Optical Port :-	Lead Seal		Optical Port:-	Lead Seal	
Meter Box Glass :-	004222 ,004223		Meter Box Glass:-	001680	

Note:- --- ---

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME B. T. Gurao
DATE 31.10.08

B. D. Fulpagar
31.10.08

D. Apparao
31.10.08

S. S. Titare
31.10.08

D. B. Daphane
31.10.08

P. A. Kothmire
31.10.08

INT MANAGER
IPPL BHANDARDARA

Exe. Engineer
E.H.V. (O&M) Div.
M.S.E.T.C.L. Nashik Road

Executive Engineer
MSETCL, Testing Division,
Nashik Road

Ex. Engr. (Testing)
MSEDCL Nashik -

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE

ANNEXURE - 1

DATE: 31.10.08

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	27.06.2008	26.06.2008	26.06.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 30.09.2008 TO 31.10.2008
METER READING TAKEN ON DATE :- 31.10.2008 AT 13.04 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	300920410	246230	246052
KWH PAST	299550770	245111	244934
DIFFERENCE	1369640	1119	1118
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	1369640	1342800	1341600
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	10272620	10071600	10065600
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	11642260	11414400	11407200
POWER FACTOR	0.990	0.997	0.997

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME B. T. Gurao

DATE 31.10.08

PLANT MANAGER
DLHPPL BHANDARDARA

B. D. Fulpagar

31.10.08
SECT. OFFICER
P.H.E. SECT.
Bhandardara.

D. Apparao
31.10.08

S. S. Titare
31.10.08

Executive Engineer
MSETCL, Testing Division,
Nashik Road

D. B. Daphane
31.10.08

P. A. Kothmire
31.10.08

Exec. Engineer
B.H.V. (O&M) Div.
M.S.E.T.C.L. Nashik Road

Exec. Engineer (Testing)
M.S.E.T.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		

2) DUE TO DISPATCH INSTRUCTIONS

:- NIL

3) DUE TO FORCE MAJEURE

:- NIL

FOR DLHPPL

FOR MSETCL

NAME:- B. T. Gurao

DATE:- 31.10.2008

PLANT MANAGER
DLHPPL BHANDARDARA

NAME:- D. Apparao

DATE:- 31.10.2008

Exec. Engineer
E.H.V. (O&M) Dn.
M.S.E.T.C.L. Nashik Road

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK

:- NIL

2) DUE TO POLITICAL FORCE MAJEURE

:- NIL

3) DUE TO NON RELEASE OF WATER TO MDDL

:- NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER
THROUGH P. H. NO. 1 IN DEPENDABLE YEAR.

:- NIL

a) WATER FLOW METER READING RECORDED
ON 31.10.08 AT 13.04 HRS.

:- 350.30 MCM

b) WATER RELEASED DURING THIS MONTH

:- 07.70 MCM

c) CUMULATIVE WATER RELEASED UPTO

:- 07.70 MCM

DATE FROM 01.10.2008 FOR WATER YEAR 2008-

d) CUMULATIVE WATER RELEASED IN WATER
YEAR 2008-09

:- 66.20 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

FOR GOMWRD

NAME:- B. T. Gurao

DATE:- 31.10.2008

PLANT MANAGER
DLHPPL BHANDARDARA

NAME:- B. D. Fulpagar

DATE:- 31.10.2008

SECT. OFFICER
B.H.E. SECT.
Bhandardara.

DODSON - LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO. 1, BHANDARDARA

MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF SEPTEMBER - 2008

DATE : 30.09.08
TIME : 14.17

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION 100 / 1, class 0.2

PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	245111	244934
	2	2	Total kVARh - Q1	24316	25411
	3	3	Total kVARh - Q4	46	45
	4	4	Total kVAh - Q1+Q4	246656	246649
	5	5	Rate C Max kVA - Q1 + 4	12.12	12.11
	6	6	Average Power Factor kWh - Del	0.997	0.997
	7	7	Total kWh - Received	100	82
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	55	44
	10	10	Total kVAh - Q2+3	118	97
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	63.92	63.91
	*	14	Phase B Voltage	64.08	63.99
	*	15	Phase C Voltage	63.76	63.77
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	30.09.08	30.09.08
	20	20	Present Time	14.17	14.19

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	63.00	63.92	Vrn	63.00	63.91
Vyn	63.00	64.08	Vyn	63.00	63.99
Vbn	63.00	63.76	Vbn	63.00	63.77
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead Seal
Meter Box :-		D0485381	Meter Box :-		D0485382
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- ----

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
DATE 30.09.08

B. D. Fulpagar
30.09.08

D. Apparao
30.09.08

H. D. Ade
30.09.08

D. D. Daphane
30.09.08

A. P. Rathod
30.09.08

PLANT MANAGER
DLHPPL, BHANDARA

SECT. OFFICER
B.H.E. SECT.
Bhandardara

Executive Engineer
E.H.V. (O&M) Div. Nashik
M.S.E.T. Co. Ltd.

Executive Engineer
MSETCL, Testing Division,
Nashik Road

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 30.09.08

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	27.06.2008	26.06.2008	26.06.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 31.08.2008 TO 30.09.2008

METER READING TAKEN ON DATE :- 30.09.2008 AT 14.17 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	299550770	245111	244934
KWH PAST	293789220	240404	240230
DIFFERENCE	5761550	4707	4704
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	5761550	5648400	5644800
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	4511070	4423200	4420800
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	10272620	10071600	10065600
POWER FACTOR	0.990	0.997	0.997

FOR DLHPPL

NAME R. V. Jadhav
DATE 30.09.08

FOR GOMWRD

B. D. Fulpagar
30.09.08

FOR MSETCL

D. Apparao
30.09.08

FOR MSEDCCL

D. P. Daphane
30.09.08

PLANT MANAGER
DLHPPL, BHANDARDARA

SECT. OFFICER
B.H.E. SECT.
Bhandardara.

Executive Engineer
MSETCL., Testing Division,
Nashik Road

Ex. Engr. (Testing)
MSEDCCL, Nashik -

Executive Engineer
B.H.E. SECT. Bhandardara

Ex. Engr. (Testing)
MSEDCCL, Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE :-

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	-

2) DUE TO DISPATCH INSTRUCTIONS :-

NIL

3) DUE TO FORCE MAJEURE :-

NIL

FOR DLHPPL

FOR MSETCL

NAME:- R. V. Jadhav

DATE:- 30.09.2008

PLANT Bhandardara
DLHPPL, BHANDARDARA

NAME:- D. Apparao

DATE:- 30.09.2008

As per the order
of the Board of Directors
of the Company dated
30.09.2008.

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK :-

NIL

2) DUE TO POLITICAL FORCE MAJEURE :-

NIL

3) DUE TO NON RELEASE OF WATER TO MDDL :-

NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER
THROUGH P. H. NO. 1 IN DEPENDABLE YEAR. :-

NIL

a) WATER FLOW METER READING RECORDED
ON 30.09.08 AT 14.17 HRS. :-

342.60 MCM

b) WATER RELEASED DURING THIS MONTH :-

32.60 MCM

c) CUMULATIVE WATER RELEASED UPTO
DATE FROM 01.10.2008 FOR WATER YEAR 2008- :-

N. A.

d) CUMULATIVE WATER RELEASED IN WATER
YEAR 2008-09 :-

58.50 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

FOR GOMWRD

NAME:- R. V. Jadhav

DATE:- 30.09.2008

PLANT Bhandardara
DLHPPL, BHANDARDARA

NAME:- B. D. Fulpagar

DATE:- 30.09.2008

SECT. OFFICER

B.H.E. SECT.

DODSON - LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO. 1, BHANDARDARA

MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF AUGUST - 2008

DATE : 31.08.08
TIME : 13.40

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION 100 / 1, class 0.2 PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	240404	240230
	2	2	Total kVARh - Q1	23974	25064
	3	3	Total kVARh - Q4	46	45
	4	4	Total kVAh - Q1+Q4	241936	241931
	5	5	Rate C Max kVA - Q1 + 4	12.09	12.08
	6	6	Average Power Factor kWh - Del	0.997	0.997
	7	7	Total kWh - Received	100	82
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	55	44
	10	10	Total kVAh - Q2+3	118	97
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	63.33	63.36
	*	14	Phase B Voltage	63.68	63.50
	*	15	Phase C Voltage	63.18	63.06
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	31.08.08	31.08.08
	20	20	Present Time	13.40	13.42

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	62.00	63.33	Vrn	62.00	63.36
Vyn	62.00	63.68	Vyn	62.00	63.50
Vbn	62.00	63.18	Vbn	62.00	63.08
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead Seal
Meter Box :-		D0485321	Meter Box :-		D0485322
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- ----

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
DATE 31.08.08

B. D. Fulpagar
31.08.08

A. V. Naik
31.08.08

S.S. Titare
31.08.08

P. A. Kothmire
31.08.08

K. S. Thakur
31.08.08

PLANT MANAGER
DLHPPL BHANDARDARA

SECT. OFFICER
B.H.E. SECT.
Bhandardara.

Exe. Engr. (Testing)
Nashik Road

Exe. Engr. (Testing)
Nashik Road

Ex. Engr. (Testing)
MSEDCL Nashik

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 31.08.08

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	27.06.2008	26.06.2008	26.06.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 31.07.2008 TO 31.08.2008

METER READING TAKEN ON DATE :- 31.08.2008 AT 13.40 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	293789220	240404	240230
KWH PAST	289364840	236789	236617
DIFFERENCE	4424380	3615	3613
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	4424380	4338000	4335600
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	86690	85200	85200
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	4511070	4423200	4420800
POWER FACTOR	0.990	0.997	0.997

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
DATE 31.08.08

B. D. Fulpagar
31.08.08

A. V. Naik
31.08.08

S. S. Titare
31.08.08

P. A. Kothmire
31.08.08

K. S. Thakur
31.08.08

LANT MANAGER
LHPPL BHANDARDARA

SECT. OFFICER
B.H.E. SECT.
Bhandardara.

Exe. Engr. (Testing)
Nashik Road

Ex. Engr. (Testing)
M.S.E.D.C.L. Nashik -

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
11-08-08	19.12	19.39	0.45	132 KV MSETCL Grid Failed.
	20.29	20.41	0.20	Unit was OFF to charge 132 KV Igatpuri S/S.

2) DUE TO DISPATCH INSTRUCTIONS


:- NIL


3) DUE TO FORCE MAJEURE

:- NIL

FOR DLHPPL

FOR MSETCL


NAME:- R. V. Jadhav
DATE:- 31.08.2008
PLANT MANAGER
DLHPPL BHANDARDARA


NAME:- A. V. Naik
DATE:- 31.08.2008
Exe. Engr. (Test)
Nashik Road

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK

:- NIL

2) DUE TO POLITICAL FORCE MAJEURE

:- NIL

3) DUE TO NON RELEASE OF WATER TO MDDL

:- NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER THROUGH P. H. NO. 1 IN DEPENDABLE YEAR.

:- NIL

a) WATER FLOW METER READING RECORDED ON 31.08.08 AT 13.40 HRS.

:- 310.00 MCM

b) WATER RELEASED DURING THIS MONTH

:- 25.20 MCM

c) CUMULATIVE WATER RELEASED UPTO DATE FROM 01.10.2008 FOR WATER YEAR 2008-

:- N. A.


d) CUMULATIVE WATER RELEASED IN WATER YEAR 2008-09


:- 25.90 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

FOR GOMWRD


NAME:- R. V. Jadhav
DATE:- 31.08.2008
PLANT MANAGER


NAME:- B. D. Fulpagar
DATE:- 31.08.2008
SECT. ENGINEER
BHANDARDARA

DODSON - LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO. 1, BHANDARDARA

MONTHLY JOINT VISUAL METER READINGS FOR THE MONTH OF JULY - 2008

DATE : 31.07.08
TIME : 14.19

METER SPECIFICATION: MAIN METER - 0002173601, CHECK METER - 0002173600

CT SPECIFICATION 100 / 1, class 0.2

PT SPECIFICATION: 132000/sqrt.3 / 110/sqrt.3

MULTIPLYING FACTOR: 1200

TYPE	ID NO.	SEQ.	PARAMETER	MAIN METER READING	CHECK METER READING
Normal	1	1	Total kwh - Delivered	236789	236617
	2	2	Total kVARh - Q1	23728	24814
	3	3	Total kVARh - Q4	43	42
	4	4	Total kVAh - Q1+Q4	238311	238308
	5	5	Rate C Max kVA - Q1 + 4	8.87	8.85
	6	6	Average Power Factor kWh - Del	0.992	0.991
	7	7	Total kWh - Received	100	82
	8	8	Total kVARh - Q2	3	3
	9	9	Total kVARh - Q3	55	44
	10	10	Total kVAh - Q2+3	118	97
	11	11	Rate C Max kVA - Q2 + 3	0.00	0.00
	12	12	Average Power Factor kWh - Rec	1.000	1.000
	*	13	Phase A Voltage	66.08	66.07
	*	14	Phase B Voltage	66.40	66.32
	*	15	Phase C Voltage	65.97	65.90
	*	16	Phase A Current	0.00	0.00
	*	17	Phase B Current	0.00	0.00
	*	18	Phase C Current	0.00	0.00
	19	19	Present Date	31.07.08	31.07.08
	20	20	Present Time	14.19	14.06

Main Meter			Check Meter		
	At MTC	Display		At MTC	Display
Ir	0.00	0.00	Ir	0.00	0.00
Iy	0.00	0.00	Iy	0.00	0.00
Ib	0.00	0.00	Ib	0.00	0.00
Vrn	65.00	66.08	Vrn	65.00	66.07
Vyn	65.00	66.40	Vyn	65.00	66.32
Vbn	65.00	65.97	Vbn	65.00	65.90
Seals			Seals		
MTC :-		Lead Seal	MTC :-		Lead seal
TTB :-		Lead Seal	TTB :-		Lead Seal
Meter Box :-		D0485273	Meter Box :-		D0485274
Optical Port :-		Lead Seal	Optical Port:-		Lead Seal
Meter Box Glass :-		004222 ,004223	Meter Box Glass:-		001680

Note:- ----

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
DATE 31.07.08

B. D. Fulpagar
31.07.08

D. Apparao
31.07.08

M. R. Gupta
31.07.08

D. B. Daphane
31.07.08

P. A. Kothmire
31.07.08

MANAGER
BHANDARDARA

Executive Engineer
E.H.V. (O&M) Div. Nsk.Rd
M.S.E.T Co. Ltd.

Ex. Engr. (Testing)
M.S.E.D.C.L. Nsk.Rd

Ex. Engineer (Testing)

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

MONTHLY TARIFF INVOICE AND SUPPLEMENTAL INVOICE ANNEXURE - 1

DATE: 31.07.08

DETAILS OF METER	GENERATOR POINT (DESIGN ENERGY)	EXPORT POINT (MAIN METER)	MSEB METER (CHECK METER)
MAKE	LANDIS & GYR	ABB	ABB
METER SR. NO.	73932341	02173601	02173600
C.T. RATIO	1000 / 1 A	— / 1 A	— / 1 A
P.T. RATIO	11 KV / 110 V	11 KV / 110 V	11 KV / 110 V
CALIBRATED ON DATE	27.06.2008	26.06.2008	26.06.2008
ACTUAL C.T. RATIO	1000 / 1 A	100 / 1 A	100 / 1 A
ACTUAL P.T. RATIO	11 KV / 110 V	132 KV / 110 V	132 KV / 110 V
MULTIPLYING FACTOR	1 FOR MW	1200	1200

ANNEXURE - 2

METER READING PERIOD:- FROM 30.06.2008 TO 31.07.2008
METER READING TAKEN ON DATE :- 31.07.2008 AT 14.19 Hrs.

	GENERATOR POINT	EXPORT POINT (MAIN)	MSEB'S CHECK METER
KWH PRESENT	289364840	236789	236617
KWH PAST	289278150	236718	236546
DIFFERENCE	86690	71	71
UNITS CONSUMED DURING TESTING	0	0	0
MULTIPLYING FACTOR	1	1200	1200
UNITS DELIVERED DURING THE MONTH	86690	85200	85200
UNITS DELIVERED UPTO LAST MONTH DURING WATER YEAR	0	0	0
CUMULATIVE UNITS DELIVERED UPTO END OF THIS MONTH OF WATER YEAR 2008-09	86690	85200	85200
POWER FACTOR	0.983	0.992	0.991

FOR DLHPPL

FOR GOMWRD

FOR MSETCL

FOR MSEDCL

NAME R. V. Jadhav
DATE 31.07.08

B. D. Fulpagar
31.07.08

D. Apparao
31.07.08

M. R. Gupta
31.07.08

D. B. Daphane
31.07.08

P. A. Kothmire
31.07.08

PLANT MANAGER
DLHPPL, BHANDARDARA

SECT. OFFICER
B.H.E. SECT.
Bhandardara

Zone

DODSON-LINDBLOM HYDRO POWER PVT. LTD.

1 X 12MW POWER HOUSE NO.1, BHANDARDARA

ANNEXURE - 3

A) SHORTFALL ATTRIBUTABLE TO MSETCL

1) DUE TO BOARD SYSTEM FAILURE :- NIL

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
---	---	---	---	---

2) DUE TO DISPATCH INSTRUCTIONS :- NIL

3) DUE TO FORCE MAJEURE :- NIL

FOR DLHPPL

FOR MSETCL

NAME:- R. V. Jadhav

DATE:- 31.07.2008

PLANT MANAGER
DLHPPL BHANDARDARA

NAME:- D. Apparao

DATE:- 31.07.2008

Executive Engineer
E.H.D. (C&D) DIV. MSR, RG
M.S.E.D. CHITTO

B) SHORTFALL ATTRIBUTABLE TO GOMWRD

1) DUE TO NON RELEASE OF WATER THROUGH PENSTOCK :- NIL

2) DUE TO POLITICAL FORCE MAJEURE :- NIL

3) DUE TO NON RELEASE OF WATER TO MDDL :- NIL

4) DUE TO NON RELEASE OF 200 MCM OF WATER THROUGH P. H. NO. 1 IN DEPENDABLE YEAR. :- NIL

a) WATER FLOW METER READING RECORDED ON 31.07.08 AT 14.19 HRS. :- 284.80 MCM

b) WATER RELEASED DURING THIS MONTH :- 0.70 MCM

c) CUMULATIVE WATER RELEASED UPTO DATE FROM 01.10.2008 FOR WATER YEAR 2008-09 :- N. A.

d) CUMULATIVE WATER RELEASED IN WATER YEAR 2008-09 :- 0.70 MCM

DATE	TIME		PERIOD Hrs.	REASON
	FROM	TO		
-	-	-	-	NA

FOR DLHPPL

FOR GOMWRD

NAME:- R. V. Jadhav

DATE:- 31.07.2008

PLANT MANAGER
DLHPPL BHANDARDARA

NAME:- B. D. Fulpagar

DATE:- 31.07.2008

SECT. OFFICER
B.H.E. SECT.