

 <p align="center">CDM: Form for submission of queries from DOEs to the Methodologies Panel regarding the application of approved methodologies (version 01) <i>(To be used by DOEs for presenting questions / proposals / amendments related to the applicability of approved methodology)</i></p>	
Name of the entity (DOE) submitting this form	Bureau Veritas Certification
Reference number and title of the approved methodologies	ACM0002/version 09 "Consolidated baseline methodology for grid-connected electricity generation from renewable sources"
Title/Subject (give a short title or specify the subject of your submission, maximum 200 characters):	Clarification on monitoring parameter TEG _y of ACM0002 version 09
Attach CDM-PDD example of project activity where applicability raises problem:	<input type="checkbox"/> Yes, is attached.
Date and signature for the DOE	14/02/2012
<p>Submitted queries</p> <p>Please use the space below to substantiate the queries relating to the application of approved methodologies. If the questions are related to a project activity under development or implementation, please describe the context in which they arose. If you are proposing amendments to existing methodologies, please specify the text you want to change or introduce. If necessary, attach files or refer to sources of relevant information.</p> <p>If you have a question relating to the application of an approved methodology, please specify and provide reference to the exact project activity to which it applies.</p> <p>>></p> <p>The clarification is requested to UNFCCC regarding the monitoring of the parameter TEG_y (Total electricity produced by the project activity, including the electricity supplied to the grid and the electricity supplied to internal loads in year y) referred in the approved methodology ACM0002 version 09.</p> <p>We notice that in ACM0002 version 10 and all its later versions, the applicability condition on monitoring of TEG_y has been explicitly specified, i.e. only applicable to hydro power project activities with a power density of the project activity (PD) greater than 4 W/m² and less than or equal to 10W/m². However, no applicability condition on monitoring of TEG_y was specified in ACM0002 version 09.</p> <p>We would therefore seek to clarify in the case of a hydro power project with a PD greater than 10W/m² which applied of methodology ACM0002 version 09 and had been registered, whether the Revision of monitoring plan is necessary when the parameter TEG_y was not included in the registered monitoring plan.</p>	
<p>If you propose an amendment to an approved methodology, please provide reasons.</p> <p>N.A.</p>	
<p>In case you propose the amendment to the approved methodologies, please provide your draft below, if not included in an annex:</p>	

N.A.	
<i>Date of submission of contribution:</i>	14/02/2012
Information to be completed by the secretariat	
Date when the form was received at UNFCCC secretariat	
Date of transmission to the Meth Panel and Executive Board	