
 <p align="center"><b>CDM: Form for submission of queries from DOEs to the Methodologies Panel regarding the application of approved methodologies (version 01)</b>  <i>(To be used by DOEs for presenting questions / proposals / amendments related to the applicability of approved methodology)</i></p>	
Name of the entity (DOE) submitting this form	SGS United Kingdom Ltd.
Reference number and title of the approved methodologies	ACM0002 "Consolidated baseline methodology for grid connected electricity generation from renewable sources" Version 07 EB36
Title/Subject (give a short title or specify the subject of your submission, maximum 200 characters):	Request for clarification on calculation of EG <sub>historical</sub>
Attach CDM-PDD example of project activity where applicability raises problem:	<input type="checkbox"/> Yes, it is attached
Date and signature for the DOE	 Signature: Name: Siddharth Yadav Date: 14 <sup>th</sup> October 2008
<b>Submitted queries</b> Please use the space below to substantiate the queries relating to the application of approved methodologies. If the questions are related to a project activity under development or implementation, please describe the context in which they arose. If you are proposing amendments to existing methodologies, please specify the text you want to change or introduce. If necessary, attach files or refer to sources of relevant information.	
<b>If you have a question relating to the application of an approved methodology, please specify and provide reference to the exact project activity to which it applies.</b>	

We would like to ask for clarification regarding calculation of the historical electricity generation of a rehabilitated plant according to ACM 0002. The factor  $EG_{\text{historical}}$  shall be calculated as the minimum of 5 years of historical generation data, excluding abnormal years.

The hydro plant to be rehabilitated was affected by an earthquake in July 1990, which caused landslides to occur in its watershed area. This caused a large amount of silt to flow into the reservoir, and caused existing silt to move and cover the intake tower. The plant generation capacity was partially restored in 1995. The company rehabilitating the plant attempted to utilize the existing intake, but the difficulty experienced in dredging the intake area and the inability to close the intake grills prevented a proper rehabilitation of the waterway and turbines. The plant was shut down again in 1999 and has not produced electricity since.

Generation figures for the plant since 1985 are as follows:

	Power (GWh)		Power (GWh)		Power (GWh)		Power (GWh)
1985	382	1991	0	1997	181	2003	0
1986	355	1992	0	1998	82	2004	0
1987	263	1993	0	1999	100	2005	0
1988	333	1994	0	2000	0	2006	0
1989	203	1995	0	2001	0	2007	0
1990	91	1996	163	2002	0	2008	0

Which period should be used for calculation of  $EG_{\text{historical}}$ ?

**If you propose an amendment to an approved methodology, please provide reasons.**

Not applicable.

**In case you propose the amendment to the approved methodologies, please provide your draft below, if not included in an annex:**

Not applicable.

*Date of submission of contribution:*

14<sup>th</sup> October 2007

**Information to be completed by the secretariat**

Date when the form was received at UNFCCC secretariat

Date of transmission to the Meth Panel and Executive Board