
	<b>CDM: Response form for Request for revision of approved methodologies (version 01.1)</b>
Date of Meth Panel meeting:	26 - 30 March 2007
Title and number of Request for revision	"Approach for the exclusion of immaterial parts of a multinational grid" AM_REV_0027
<b>Summary of the query:</b> Please use the space below to summarize the request for revision on the related approved methodologies.	
<p>The project participant suggests the introduction of a quantitative indicator in ACM0002 in order to <b>facilitate the exclusion of certain parts of a grid system from the project electricity system</b> or customer electricity system if the power transmission between the grid system that is proposed to be excluded from the project electricity system is immaterial compared to the total power consumption within the remainder of the project or customer electricity system.</p> <p>Reasons for proposing amendment mentioned by project participant:          In its current wording ACM0002 can lead to a situation where the project electricity system can potentially cover a large number of countries (e.g. an international grid) although the power supply contribution to that electricity system by some grids (e.g. from very small countries) may be immaterial when compared to the total amount of power consumed within the electricity system. Despite the immateriality of the contribution, new data sources will have to be accessed and the approval of a DNA (which may not exist) is required. An introduction of a quantitative indicator for exclusion of grids due to immateriality will allow for a more efficient (and still accurate) calculation of baseline emissions.</p>	
<b>Recommendation by the Meth Panel:</b>	
(a) Please use the space below to provide amendments /changes (in your expert view, if necessary).	
It is suggested to accommodate the DOEs request when ACM0002 will be revised the next time. To broaden the applicability of the changes, the Meth Panel will recommend a broader wording of the amendment than suggested by the DOE. The Meth Panel recommends not to revise the methodology at this point in time.	
(b) Please use the space below for providing guidance, as per Para 93 of EB25 Report, on what type of projects need to revise the PDD as a consequence of the suggested revision, if the recommendation is to revise the methodology.	
N/A.	
<b>Answer to authors of the request for revision by the Meth Panel :</b>	
Please use the space below to provide an answer to the authors of the above query	
Until the methodology will be revised, project participants are invited to submit a request for deviation for their specific case.	



Signature of the Meth Panel Chair

Date: 30/03/2007

(Akihiro Kuroki)



Signature of the Meth Panel Vice-Chair

Date: 30/03/2007

(Xuedu Lu)

**Information to be completed by the secretariat**

F-CDM-AM	AM-REV-0027
Name of the authors of the query:	TUEV-SUED
Date when the form was received at UNFCCC secretariat	30 March 2007
Date of transmission to the EB	30 March 2007
Date of posting in the UNFCCC CDM web site	30 March 2007