

**Indicative simplified baseline and monitoring methodologies
for selected small-scale CDM project activity categories***III.I. Avoidance of methane production in wastewater treatment through replacement of anaerobic lagoons by aerobic systems (cont)***TYPE III - OTHER PROJECT ACTIVITIES**

Project participants shall take into account the general guidance to the methodologies, information on additionality, abbreviations and general guidance on leakage provided at <http://cdm.unfccc.int/methodologies/SSCmethodologies/approved.html>.

III.I. Avoidance of methane production in wastewater treatment through replacement of anaerobic lagoons by aerobic systems**Technology/measure**

1. This project category comprises measures that avoid the production of methane from biogenic organic matter in wastewaters being treated in anaerobic lagoons. Due to the project activity, the anaerobic lagoons¹ (without methane recovery), are substituted by aerobic systems. The project activity does not recover or combust methane in wastewater treatment facilities (unlike III H).

Measures are limited to those that result in emission reductions of less than or equal to 60 kt CO₂ equivalent annually

Boundary

2. The project boundary is the physical, geographical site where the wastewater treatment takes place.

Project Activity Emissions

3. Project activity emissions consists of:

- (i) CO₂ emissions related to the power used by the project activity facilities. Emission factors for grid electricity or diesel fuel use shall be calculated as described in category I.D;
- (ii) Methane emissions during the aerobic wastewater treatment;
- (iii) Methane emissions from the decay of the sludge generated by the aerobic systems, if the sludge is disposed to decay anaerobically in a landfill without methane recovery.

$$PE_y = PE_{y,power} + PE_{y,ww,treatment} + PE_{y,sludge}$$

Where:

¹ Anaerobic lagoons are ponds deeper than 2 meters, without aeration, temperature above 15°C, at least during part of the year, on a monthly average basis, and with a volumetric loading rate of Chemical Oxygen Demand above 0.1 kg COD/(m³.day).

**Indicative simplified baseline and monitoring methodologies
for selected small-scale CDM project activity categories***III.I. Avoidance of methane production in wastewater treatment through replacement of anaerobic lagoons by aerobic systems (cont)*

PE_y	project activity emissions in the year “y” (tCO ₂ e)
PE_{y,power}	emissions on account of electricity or diesel consumption in the year “y”
PE_{y,ww,treatment}	emissions from the aerobic wastewater treatment in the year “y” ¹
PE_{y,sludge}	emissions from anaerobic decay of the sludge produced in the year “y”

$$PE_{y,ww,treatment} = Q_{ww,y} * COD_y * B_o * MCF_{aerobic} * GWP_{CH_4}$$

Where:

Q_{ww,y}	Volume of the wastewater treated during the year “y” (m ³)
COD_y	Chemical oxygen demand of effluent entering the lagoons in the year y (tonnes).
B_o	methane producing capacity for the wastewater (IPCC default value for domestic wastewater of 0.21 kg CH ₄ /kg.COD) ²
MCF_{aerobic}	methane correction factor for the wastewater treatment in aerobic systems (MCF higher value of 0.1 for well managed systems, or 0.4 for poorly managed or overloaded systems as per table III.H.1 in category III.H)
GWP_{CH₄}	Global Warming Potential for CH ₄ (value of 21)

$$PE_{y,sludge} = S_y * DOC_{y,s} * MCF_s * DOC_F * F * 16/12 * GWP_{CH_4}$$

Where:

PE_{y,sludge}	Methane emissions from the anaerobic decay of the final sludge generated in the wastewater system in the year “y” (tCO ₂ e)
S_y	Amount of sludge generated by the wastewater treatment in the year y (tonnes).
DOC_{y,s}	Degradable organic content of the sludge generated by the wastewater treatment in the year y (fraction). It shall be measured by sampling and analysis of the sludge produced, and estimated ex-ante using the IPCC default values of 0.05 for domestic sludge (wet basis, considering a default dry matter content of 10 percent) or 0.09 for industrial sludge (wet basis, assuming dry matter content of 35 percent).
MCF_s	Methane correction factor of the landfill that receives the final sludge, estimated as described in category AMS III.G.
DOC_F	Fraction of DOC dissimilated to biogas (IPCC default value is 0.5).
F	Fraction of CH ₄ in landfill gas (IPCC default is 0.5).

¹ These methane emissions occur due to anaerobic pockets that may occur in aerobic systems, and are considered in 2006 IPCC Guidelines. Methane emissions through inefficiency of the wastewater treatment and presence of degradable organic carbon in treated wastewater will be neglected, since they would also be accounted for in the baseline scenario, and would approximately cancel each other.

² The IPCC default value of 0.25 kg CH₄/kg COD was corrected to take into account the uncertainties. For domestic waste water, a COD based value of B_{o,ww} can be converted to BOD₅ based value by dividing it by 2.4 i.e. a default value of 0.504 kg CH₄/kg BOD can be used.

**Indicative simplified baseline and monitoring methodologies
for selected small-scale CDM project activity categories***III.I. Avoidance of methane production in wastewater treatment through replacement of anaerobic lagoons by aerobic systems (cont)***Baseline**

4. The baseline scenario is the situation where, in the absence of the project activity, degradable organic matter in wastewater is treated in anaerobic lagoons and methane is emitted to the atmosphere. Baseline emissions are calculated as the amount of methane produced in the anaerobic system that was replaced with aerobic system.

5. The baseline emissions from the lagoon are estimated using the procedure defined under category AMS III.H.:

$$BE_y = \sum(Q_{ww,y,m} * COD_{y,m}) * Bo * MCF_{lagoon} * GWP_{CH_4}$$

Where:

BE_y Baseline emissions in the year “y” (tCO₂e).

Q_{ww,y,m} Volume of the wastewater treated during the months m, during year “y”, for the months with average lagoon temperature above 15°C (m³)

COD_{y,m} Chemical oxygen demand of effluent entering the lagoons in the year y (tonnes/m³) for the months with average lagoon temperature above 15°C. It shall be directly measured, since the effluent that goes into the lagoon in the baseline situation is the same as the one that goes into the aerobic system in the project situation.

MCF_{lagoon} methane correction factor for the wastewater treatment in anaerobic lagoons (MCF lower value of 0.8 as per table III.H.1 under AMS III.H).

Leakage

6. If the aerobic treatment technology is equipment transferred from another activity or if the existing equipment is transferred to another activity, leakage effects at the site of the other activity are to be considered.

Monitoring

7. The emission reduction achieved by the project activity will be measured as the difference between the baseline emission and the sum of the project emission and leakage.

$$ER_y = BE_y - (PE_y + Leakage_y)$$

Where:

ER_y Emission reduction in the year “y” (tCO₂e)

The amount of COD treated in the wastewater treatment plant shall be measured regularly. The wastewater flow shall be recorded.



**Indicative simplified baseline and monitoring methodologies
for selected small-scale CDM project activity categories**

III.I. Avoidance of methane production in wastewater treatment through replacement of anaerobic lagoons by aerobic systems (cont)

8. The yearly amount of sludge produced (S_y) shall be directly measured by weight or indirectly by its volume and density. Its degradable organic content ($DOC_{y,s}$) will be measured by representative sampling and analysis, in case the default value is not used.